

Power System Needs 2030 North-South Interconnections East

Where would investing in infrastructure until 2030 deliver the most benefits to Europeans?

The present document presents a selected set of results of ENTSO-E's System needs study for the NSI East PCI corridor and shows where and to what extent investing would contribute to market integration, improved security of supply and increased sustainability.

This document presents 3 hypothetical states of the electricity transmission network in the year 2030, in the National Trends scenario based on National Energy and Climate Plans:

- › **No investment after 2020:** a hypothetical year 2030 where Europe stopped all grid development after mid-2020.
- › **SEW-based needs 2030:** a hypothetical year 2030 where the needs for capacity increases after 2025 identified by ENTSO-E's System Needs study have been addressed (Figure 1). These needs represent the combination of cross-border capacity increases that minimises overall system cost. Only part of these needs are addressed by projects of the TYNDP 2020 portfolio.
- › **Portfolio 2030:** a hypothetical year 2030 where all projects of the TYNDP 2020 portfolio that are foreseen to commission until 2030 have been built (Figure 2).



For full details on the pan-European system needs identified in 2030 and 2040

tyndp.entsoe.eu/system-needs



For a detailed analysis of the situation in specific countries, refer to the Country Needs Factsheets

click [here](#) or scan the qr-code

Key messages of the NSI East PCI Corridor

Development of the transmission system Infrastructure is needed in the NSI East PCI Corridor to mitigate high price differentials between countries, address system adequacy deficiencies, accommodate significant changes in the generation mix, improve system flexibility and stability to support variable RES integration, reduce curtailment, reduce internal bottlenecks and manage loop flows.

1. The grid in the NSI East Corridor, especially in the Balkan Peninsula, is somewhat sparse, which could, in certain operational regimes, lead to insufficient transfer capacities. The increase of transfer capacities (both cross-border and internal) is a prerequisite for market integration in the Corridor.
2. Application of the general ENTSO-E scenarios on Turkey showed high needs for transmission capacity increase between Turkey and, primarily, Greece and Bulgaria. If these needs are fulfilled in a timely manner, the impact on all projects located in the Balkans could be considerable.
3. One of the main barriers to power exchanges in the region is relative to the integration of the Italian Peninsula, which implies the need to further develop the transmission capacity at the North-Italian boundary in order to share resources and to exploit new renewable generation.
4. To achieve EU climate goals, integration of system grids of EU and third countries plays an important role. Investments in transmission infrastructure between EU and Balkans countries are effective means to promote the energy transition, integration of renewables, security of supply, as well as regional and local socio-economic welfare, economic cooperation, peace and solidarity.




Figure 1 – Needs identified in ENTSO-E’s System Needs study for the 2030 horizon. The study investigated the combination of potential increases in cross-border network capacity that minimizes the total system costs. These capacity increases are additional to the 2025 network (composed of projects under construction or in advanced stage and expected to be in service in 2025).

Market Integration

Increasing capacity for cross-border electricity flows supports market integration, with price convergence increasing between bidding zones. Increased cross-border exchanges and distributed generation will also create stresses for national grids and trigger needs for internal reinforcements.

Convergence in marginal costs of electricity

By connecting more consumers with more producers, grid development allows a better use of the cheapest generation. As a result, European countries can exchange electricity to replace expensive generation with cheaper one and prices all over Europe tend to converge. On the opposite, limiting exchange capacity alters market integration and would result in splits between regional market prices. Fragmented markets therefore lead to artificially high marginal costs in some countries, with direct impact on consumers' electricity bills. According to the methodology developed by the Interconnection Target Expert Group, need for additional interconnections should be investigated on all borders with a spread above 2 €/MWh.

Increased cross-border transmission capacity in the SEW-based needs and Portfolio2030 cases tends to reduce the differences in marginal costs in between neighboring bidding zones. This is visible in Figure 3, where the spread in marginal cost is significantly reduced compared to the situation where Europe would stop all investments.

Europe increases its socio-economic welfare by **4.8 billion** euro/year in the SEW based needs case, and by **3.6 billion** euro/year in the Portfolio 2030 case, compared to the "No investment after 2020" case.

Difference in marginal cost of electricity between neighbouring bidding zones, in €/MWh




Figure 3a – No investment after 2020




Figure 3b – SEW-based needs 2030

- < 2.00 €/MWh
- 2.00–5.00 €/MWh
- 5.00–10.00 €/MWh
- > 10.00 €/MWh




Figure 3c – Portfolio 2030

Because of the trend highlighted above, countries with high marginal costs tend to see these costs decrease and countries with low marginal costs tend to see an increase (Figure 4).

The net annual balance shows that, for most countries, reinforcing the cross-border grid will reinforce the existing tendency to import or export (Figure 5). For Germany, the switch from importer to exporter is due to the possibility to export additional RES in 2030.




Figure 4 – Average marginal cost per country, in euro/MWh




Figure 5 – Net annual balance in TWh

Reduced congestion on borders

Constraint duration refers to the percentage of hours per year where the cross-border flow of energy reaches 100 % of the commercial capacity on the border, meaning it is congested. Reinforcing cross-border capacities reduces congestion and allow European countries to exchange more energy, in total at European level an additional 256 TWh/year would be exchanged in 2030 (in SEW-based needs), relative to the situation where Europe would not invest in the grid after 2025.

Many borders with low transmission capacity are often loaded at their maximum available capacity and are characterised by high price spread. This clearly indicates the necessity to increase the transmission capacity with new cross-border projects.



Figure 6 – Percentage of hours per year where the flow of electricity reaches 100 % of the Net Transfer Capacity on the border (constraint duration), in No investment after 2020 (left), SEW-based needs (middle) and Portfolio 2030 (right)



**For the exact values of
constraint duration**

tyndp.entsoe.eu/system-needs

Unlocking 2030 barriers

ENTSO-E has identified in the European power system a set of main boundaries (Figure 7).

Figure 8 represents the overall diminution of wholesale market volume (gains in socio-economic welfare) when the total transmission capacity across the boundary increases from the current situation (first point of the curve). Steep curves indicate high needs for further integration of the markets across the boundaries.

Capacity increase on all boundaries in the NSI East Corridor would lead to significant growth in socio-economic welfare, in a range varying from below 100 million euros per year, for Boundaries 9 (South-East integration) and 10 (Eastern

Balkan), all the way up to several times that much for Boundary 4 (Nordics/Baltics to Continental East Europe), Boundary 6 (Central East integration) and Boundary Turkey-South Balkan region. The Turkey-South Balkan boundary (Boundary A in Figure 8) possesses noteworthy potential for further development, both due to the reference capacity across the boundary being set to zero and the steep slope of the delta-SEW growth curve.

One of the main challenges in the region is the integration of the Italian peninsula (northern boundary, borders with the Balkans and Tunisia), together with the mitigation of internal bottlenecks among the six different Italian price zones, and the integration of Corsica.




Figure 7 – TYNDP 2020 10 main boundaries




Figure 8 – Increase in socio-economic welfare (SEW) when the transmission capacity increases from the current situation, on main boundaries located in the NSI East PCI Corridor, in the NT2030 scenario

Sustainability

Investing in electricity transmission infrastructure will be key to enable Europe to achieve the the Green Deal and the Paris Agreement. By allowing electricity from RES to be exported across borders, addressing system needs allows Europe to save 47 TWh of curtailed energy and avoid over 41 Mtons of CO₂ emissions each year until 2030 (compared to a future where Europe would stop investing in the grid after 2020).

A drop in curtailed energy

Increasing the exchange capacity in Europe helps the integration of renewable energy by offering more opportunities to RES power plants to be used. By taking advantage of the different energy mix over Europe and the different RES peaking period between countries, the SEW-based needs and the TYNDP portfolio decrease significantly the curtailed energy.

To ease comparison between countries, curtailed energy is presented both in absolute value (in TWh per year) (Figure 9) and as a share of RES generation (Figure 10).




Figure 9 – Curtailed energy per country in TWh




Figure 10 – Curtailed energy per country as a share of RES generation

In addition to RES, some thermal power plants emit very low CO₂ volume while generating electricity. This is the case of nuclear and biofuel power plants. New exchange capacities can increase the use of these generation when they are not used at full load. Indeed, these generation capacities have

in general a low marginal cost and can replace other more expensive and CO₂ emitting thermal power plants in other countries. Figure 11 and 12 show the remaining energy available from nuclear and biofuel power plants in different grid configurations.




Figure 11 – CO₂ free dispatchable available energy from nuclear and gas generation, in TWh




Figure 12 - CO₂-free dispatchable available energy from nuclear and gas generation as a share of the total CO₂-free dispatchable generation

Reduced CO₂ emissions

By allowing a better integration of non-CO₂ emitting generation, increased cross-border network capacity leads to a reduction of CO₂ emissions, of 41Mton per year in 2030 in the SEW-based needs case compared to the case without grid expansion after mid-2020. This highlights the important role of the network in the path toward carbon neutrality.

The methodology used to identify the SEW-based needs take CO₂ emissions into account in socio-economic welfare only partially, via the ETS CO₂ price which producers have to pay

when they emit CO₂. However, the ETS CO₂ prices of 28 EUR/ton of CO₂ in 2030 is not sufficient to properly decrease CO₂ emissions to an extent consistent with EU climate ambitions. This explains the relatively reduced impact of the SEW-based Needs.

CO₂ emissions per country are strongly affected by the assumptions made in the scenarios, view the Country fact-sheets for more details.




Figure 13 – CO₂ emissions in Mton/year




Figure 14 – Ratio of CO₂ emissions in Mton over total generation in GWh

Further interconnections may be needed in some countries to support RES development

This indicator, part of the Interconnection Target Expert Group (ITEG) proposed indicators to assess interconnectivity, aims to reflect the electricity supply and the export potential of each country.

The indicator is expressed through a ratio between the nominal transmission capacity of the interconnection lines (thermal capacity) and the installed RES generation. A low ratio means that the RES installed generation in a country is high compared to the thermal capacity of the interconnection lines.

Figure 15 shows this indicator in 2030 in the case where Europe would stop investing in the transmission grid after 2020 (top) and with the expected grid in 2025 (bottom).

For countries in green the ratio is above 60 %, for countries in yellow it is between 30 % and 60 % while for countries in red it is below 30 %. The recommendations from the ITEG is that a ratio below 30 %, such as for Italy and Cyprus, indicates a need to investigate options for additional interconnectors.

The ITEG's proposed methodology considers 3 indicators: the spread in marginal cost between neighboring zones > 2 € (Figure 3), the ratio of the nominal transmission capacity to the installed RES generation <30 % (Figure 15) and the ratio of the nominal transmission capacity to the peak load <30 % (Figure 20). As a condition sine qua non, each new interconnector must be subject to a socioeconomic and environmental cost-benefit analysis and implemented only if the potential benefits outweigh the costs.




Figure 15 – Ratio of the nominal transmission capacity (thermal capacity) to the installed RES generation in 2030, in the case where Europe would stop all grid reinforcement after 2020 (left) and with the expected grid in 2025 (right)

Security of Supply

The future power system will integrate growing shares of renewable energy sources at all voltage levels, more power electronics either in generation or HVDC connections, a very variable mix of generation as well as large and highly variable power flows. This combination of trends translates into technical challenges including frequency, voltage and congestion management control which, if they are not addressed, may threaten security of supply at European level. Solutions lie partially in new infrastructure.

Increasing share of variable renewable generation

Comparing the installed variable RES generation to the installed conventional thermal generation, in 2025 and in 2030, shows the expected evolution of generation portfolios

towards higher share of variable RES (solar, wind) generation. The ratio increases in all countries, and the faster its evolution, the harder it is for the power system to adapt.




Figure 16 – Ratio of the installed RES generation capacity to the installed conventional generation capacity, in 2025 and 2030.

Maintaining balance between generation and demand becomes increasingly challenging

The Loss of Load Expectation (LOLE) is the expected number of hours in which the hourly load exceeds the available generating capacity and available imports. This leads to hours wherein the supply cannot be met and load will have to be curtailed.

A non-zero value of LOLE indicates only a resource inadequacy in the market. It does not indicate a risk of blackout or

load shedding, because ENTSO-E only observed the day-ahead situation, while TSOs have various tools to resolve situations of scarcity within the day. Zones without circle have LOLE values of less than 0.5 h.

MAF 2019 results do not indicate significant adequacy issues in most countries. As was the case in previous MAF editions, islands are vulnerable to loss of load¹.




Figure 17 – Loss of Load Expectation in 2025 (Mid-Term Adequacy Forecast 2019)

¹ A study conducted by Cyprus TSO upon request of Cyprus Energy Regulatory Authority for the years 2021–2023 found values of Energy Not Served <0.001 % and LOLE<1.5hours.

Hourly residual load ramp is another parameter showing the challenges of operating a system with reduced amount of controllable units, high flexibility needs in normal operation, and a requirement to guarantee the necessary volume of frequency reserves for cases of unforeseen imbalances between active power generation and demand.

The curves show the changes of residual load (demand minus variable RES) from one hour to the following hour. These curves express the response (in MW/hour) that needs to be provided by controllable generating units or interconnectors in order to maintain balance between generation and demand. Steepness of the curve is most affected by the share of RES in the generation mix and by the load, for example Germany's curve is notably different from that of other countries because it has the highest RES and highest demand of all European countries.



To read more on needs triggered by operational challenges and possible solutions

[click here](#) or scan the qr-code



TYNDP 2020 Insight report on the inertia challenge

[click here](#) or scan the qr-code





Figure 18 – Hourly residual load ramp of NSI East countries, in scenario National Trends 2025





Figure 19 – Hourly residual load ramp of NSI East countries, in scenario National Trends 2030

Reinforcing interconnections will be needed in some countries for peak load to be served at all times in 2030

According to this indicator, part of the Interconnection Target Expert Group's proposed indicators to assess interconnectivity, the domestic demand should be served through domestic generation or imports.

The indicator is expressed through a ratio between the nominal transmission capacity of the interconnection lines (thermal capacity) and the peak load. A low ratio means that the peak load in a country is high compared to the thermal capacity of the interconnection lines.

Where the nominal transmission capacity of interconnectors is below 30 % of their peak load, Member States should investigate options for additional interconnectors.

For countries in green the ratio is above 60 %, for countries in yellow it is between 30 % and 60 % while for countries in red it is below 30 %.

Figure 20 shows this indicator in 2030, if no investment is made in the cross-border transmission grid after 2020 (top) and with the expected grid in 2025 (bottom).




Figure 20 – Ratio of nominal transmission capacity (thermal capacity) to the peak load in 2030, in the case where Europe would stop all grid reinforcement after 2022 (left) and with the expected grid in 2025 (right)