

Ten-Year  
Network  
Development  
Plan 2020

# Regional Investment Plan **Continental Central South**

January 2021 · Version for ACER opinion



## Contents

1	EXECUTIVE SUMMARY.....	3
1.1	Key messages of the region .....	3
1.2	Future capacity needs.....	5
2	INTRODUCTION .....	9
2.1	Regional investment plans as foundation for the TYNDP.....	9
2.2	Legal requirements.....	10
2.3	Scope of the report .....	11
2.4	General methodology.....	12
2.5	Introduction to the region.....	12
2.6	Evolution since the RegIP 2017.....	15
3	REGIONAL CONTEXT .....	20
3.1	Present situation .....	21
3.1.1	Transmission grid.....	21
3.1.2	Power generation, consumption and exchange .....	23
3.1.3	Grid constraints .....	26
3.2	Description of the scenarios .....	27
3.3	Regional scenario towards 2040 .....	34
3.4	Future challenges in the region .....	39
3.4.1	Market simulations 2030 & 2040 scenarios.....	39
3.4.2	Additional challenges in the Region .....	50
4	REGIONAL SYSTEM NEEDS.....	56
4.1	Future capacity needs.....	56
4.2	IoSN SEW-based grid.....	57
4.2.1	Further needs investigation for 2030 and 2040 scenarios .....	59
4.3	Market and Network Results.....	60
4.3.1	2040 horizon .....	67
4.3.2	2030 horizon .....	69
5	ADDITIONAL REGIONAL STUDIES .....	72
5.1	CO2 price changes .....	72
5.2	Additional regional Studies - Conclusion .....	74
6	PROJECTS .....	76
6.1	Pan-European Projects .....	76
6.2	Regional Projects .....	80
7	LINKS TO NATIONAL DEVELOPMENT PLANS.....	96
8	APPENDIX (ADDITIONAL FIGURES).....	97
9	GLOSSARY .....	102



## 1 EXECUTIVE SUMMARY

### 1.1 Key messages of the region

The Continental Central South (CCS) region is composed of Austria (AT), France (FR), Germany (DE), Italy (IT), Slovenia (SI) and Switzerland (CH). This region covers an area that ranges from the North Sea via the Alps in the very heart of continental Europe, to the Mediterranean area.




Figure 1-1: CCS region

The ongoing transformation of the electricity system with large developments of variable wind and photovoltaic power, particularly at the edges of the CCS region; nuclear and coal phase-out; primarily gas-based thermal generation and pump storage potential in the Alps are some of the outstanding characteristics of the region that will challenge the whole future electricity system, particularly the transmission system.

At present, the CCS region is globally an exporting region and the sum of all external and internal exchanges represents about 55% of the ENTSO-E perimeter's entire exchanges. The highly meshed transmission system, particularly in the central and western part of the CCS region, has led to intense interaction between the countries involved - as well as their neighbours) on the energy transmission level. It is therefore not surprising that any transmission infrastructure development, even if concentrated in a specific part of the region, has a strong influence on the whole CCS perimeter.

The *main drivers for power system evolution* can be summarised as follows:

- Massive renewable energy sources (RES) integration

<sup>1</sup> APG also represents VUEN in RG CCS

- Efficient integration of storage plants in order to facilitate the efficient use of RES
- Nuclear phase-out and existing thermal capacity dismissing or mothballing
- Coal phase-out
- Gas dependence of thermal generation
- Wide area power flows
- Preserve system stability and security of supply (SoS)

The increasing *penetration of variable renewable generation* leads to fluctuation and high utilisation of the transmission network and a more flexible transmission grid is needed as a result. In particular, the geographical concentration of RES development - primarily in DE, IT, FR and CH, and in some cases far away from the centres of consumption - and Alpine storage, leads to amplified power exchanges in a wide transmission area.

The divergence in time-of-generation and demand, resulting from the integration of volatile RES, is another rising and sustainable challenge for the overall power system, leading to the necessity for additional transport and storage capacities as well as other innovative measures.

The *integration of storage plants* can facilitate the efficient use of RES. Considerable storage potential is available in the very centre of the region, particularly in the form of existing and planned hydro-pumped storage and hydro power plants located primarily in the Alps. Further opportunities could be considered concerning the development of distributed storage systems within, or near peripheral areas with expected higher RES penetration, to reduce local congestions.

*Nuclear phase-out*, specifically the reduction of the share of nuclear capacities in the generation mix - according to the different assumptions primarily in FR, DE and CH - has a strong impact on the electricity systems and therefore the countries' power and energy balances.

*Coal phase-out* has a strong impact on the electricity systems and therefore countries' power and energy balances.

*Thermal capacity dismissing/mothballing*, primarily due to increasing shares of electricity demand supplied by RES, renders the operation of existing plants uneconomic much earlier. This leads to structural changes of power system conditions (from overcapacity to situations of reduced adequacy), particularly in the most peripheral areas of the region such as IT. The availability of adequate grid infrastructure constitutes the basis for coping with those structural changes.

Discrepancies in the time and location of generation and consumption, particularly the integration of RES at the edges of the region and storage in the Alps, as well as structural market congestion between price zones leads to *wide area power flows* through the region, requiring investment within countries and at their borders.

Due to fundamental changes in the entire electricity system - massive RES integration, nuclear and coal phase-out, limited, and in the long run uncertain, availability of conventional power plants caused by changing market conditions - SoS investigations into single demand centres are no longer sufficient. The whole *system security* has become a key issue, and the broad consideration of all relevant parameters is necessary. Numerous projects in the CCS RegIP are being supported to ensure a secure electricity system in this changing environment, particularly in the peripheral and scarcely meshed network areas of the region.

As also highlighted in the previous TYNDPs, several *boundaries* have been already identified for the CCS region, starting from the present network constraints, and also, based on the expected evolution of the power system in the coming years and long term horizons - unless new transmission assets are developed.

The main boundaries due to market integration needs refer to the integration of the Italian peninsula (northern boundary, borders with the Balkans and Tunisia), internal bottlenecks among the six different IT price zones and the integration of Corsica, the Swiss roof, the French north-eastern border and the Austrian-German border. Moreover, the need for increased transmission capacity, within the same price zone, can be recognised in DE (due to high north to south flows) and in some parts of FR (see Regional Projects).

Critical sections due to connection of generation (particularly RES) and its integration, relate to already public and mature applications for connecting large generation plants, storage PCIs and areas with high RES penetration. Of particular relevance are the connection of offshore wind in the North Sea and Baltic Sea in DE; the connection of additional hydro power plants in CH and AT; the connection of wind in the eastern part of AT; the integration of renewable generation expected in the north of the region (primarily wind onshore and offshore in DE and FR); solar in the southern part of DE, FR and particularly IT, together with wind onshore.

*Security of supply* shows up as one of the main concerns, particularly in peripheral areas, due to thermal generation dismissing/mothballing, such as occurring in IT, DE and FR, and locally, in scarcely meshed network areas. Availability of an adequate grid infrastructure constitutes the basis for coping with those structural changes.

Because of the main drivers and network constraints explained above, several transmission expansion projects have been already planned, and *additional needs* have been investigated within the CCS region.

## 1.2 Future capacity needs

ENTSO-E's Identification of System Needs (IoSN) investigated increases in cross-border transmission capacity that would maximise overall system cost-efficiency in 2030 and 2040 (considering total network investment and generation costs). To achieve this, a panel of possible network increases was proposed to an optimiser, who chose the most cost-efficient combination. To take into account the mutual influence of capacity increases, the analysis was performed simultaneously for all borders. A European overview of these increases and of the methodology is presented in the IoSN 2020 report.

The outcomes of the market and network investigations validated the necessity of the confirmed TYNDP 2018 projects to meet market integration needs and increase sustainably of the transmission system by integrating more RES generation and improving security of supply.

In addition, based also on the results of market and network simulations in 2040 scenarios, a few additional projects covering the years up to 2040 could be developed for inclusion in present and/or future TYNDPs, over and above those TYNDP 2018 projects still to be confirmed. In light of the newly presented (and very ambitious) Green Deal targets concerning massive development of Off-Shore and On-Shore RES capacities, all the borders of the CCS region shall be investigated. For instance, the borders where it could be interesting to investigate new projects are:

- Italy - Austria
- Italy - France
- Italy - Greece

Projects on the northern Italian boundary are key to evaluating the possibility of implementing new strategic north to south corridors between Germany and Italy. Such corridors shall enable connection and energy exchanges between available load and generation capacities located in the North Sea region, with those in the Mediterranean Sea area, as well as connecting flexibility potential in the Alps region.

More in detail, identified potential investment needs within the RGCCS-perimeter expressed in terms of transmission capacity increases on top to the 2025 grid considering 2040 scenarios are illustrated in Fig. 1-2. The figure presents only cross-border transmission capacity increases because the simulator investigated only borders between countries. However national projects and internal reinforcement are vital for the grid's consistent development. Internal investment is a matter of further analysis within the scope of National Development Plans.



Figure 1-2: Increase in capacity from 2025 to 2040

In particular, as far as the long-term time horizon 2040 is concerned, the highest identified potential investment needs in the CCS region on top of the 2025 grid are located in Germany's border areas. Swiss, Austrian, and Italian borders present remarkable capacity needs. Looking at Italy, more specifically, it can be observed that Italian borders require relevant capacity increases not only on its northern border (such as IT-FR, IT-CH, and IT-AT) but also with its borders with Montenegro and Greece.

In addition, in 2040 the French border to Switzerland will also require capacity increases.

In order to understand the priority borders for capacity development (mostly planned in the coming years) additional analyses have been carried out around adapting grid 2020 to the 2030 time horizon, as

## REGIONAL INVESTMENT PLAN 2020 – CONTINENTAL CENTRAL SOUTH

depicted in figure 1-3 below. This figure presents (as for 2040 scenarios) only additional transmission capacity at cross-border level, because only borders between countries have been analysed. However, it is also worth mentioning that national projects and internal reinforcements are important for the consistent development of the grid. Internal reinforcements are a matter of further analysis within the scope of National Development Plans.




Figure 1-3: Increase in capacity from 2020 to 2030

Looking at Figure 1-2 above, it can be seen how expected capacity increase for the CCS region in the long-term 2040 time horizon, are needed since 2030 (see Fig. 1-3), such as the increases on Italian borders. However, it should be noted that 2030 IoSN analyses provide a more complete view of other capacity needs increases to be considered. In this regard, the Italian system grid reveals additional capacity increase on its North African<sup>2</sup> border by 2030 and on its internal borders.

To summarise, the results of the IoSN analyses confirm the need for new investment in transmission projects. Priority projects are already planned in the National Development Plans<sup>3</sup> and TYNDP. Fig. 1-4 shows the TYNDP 2020 projects.

Taking into account that in some cases these projects do not fully satisfy identified investment needs, further transmission projects beyond the current TYNDP could be investigated in order to verify more detailed feasibility aspects, including congestion problems on national internal networks.

<sup>2</sup> Further details are given in the following chapters

<sup>3</sup> NDPs links can be found in Chapter 6

# REGIONAL INVESTMENT PLAN 2020 – CONTINENTAL CENTRAL SOUTH



Figure 1-4: Projects<sup>4</sup> included in the TYNDP 2020

<sup>4</sup> On the Italy-Slovenia border, Project 150 status on the Italian side is 'in permitting', whereas on the Slovenian side it is 'under consideration'



## 2 INTRODUCTION

### 2.1 Regional investment plans as a foundation for the TYNDP

ENTSO-E's Ten-Year Network Development Plan (TYNDP) is the most comprehensive planning reference for the pan-European electricity transmission network. Released every even-numbered year, it presents and assesses all relevant pan-European projects at a specific time horizon, as defined by a varying set of scenarios, to describe the future development and transition of the electricity market. The TYNDP serves as basis for deriving the EU list of European Projects of Common Interest (PCI).

Regional investment plans are part of the TYNDP 2020 package, which also include, among other things, the report '[Completing the map - Power system needs in 2030 and 2040](#)' and the [Scenarios report](#), describing the scenarios serving as a basis for the IoSN and Regional Investment Plans.




Figure 2-1: Document structure overview TYNDP 2020

An essential part of the TYNDP 2020 package, the six Regional Investment Plans (RegIPs) address challenges and system needs at the regional level, for each of ENTSO-E's six system development regions (Figure 2.2).




Figure 2-2: ENTSO-E system development regions

The RegIPs are based on Pan-European market study results combined with European and/or regional network studies. They present the current situation of the region as well as future regional challenges considering different scenarios in the 2030 and 2040 time horizons.

In addition to showing the 2030 and 2040 challenges, and proper scenario grid capacities to solve many of these challenges, the RegIPs also show all relevant regional projects from the TYNDP project collection. The benefits of each of these projects will be assessed and presented in the final TYNDP publication package later in 2020.

Available regional sensitivities and other available studies are included in each RegIP to illustrate circumstances particularly relevant to that region. The operational functioning of the regional system and future challenges regarding this can also be assessed and described in the reports.

## 2.2 Legal requirements

Regulation (EU) 2019/943 Article 34 (recast of Regulation (EC) 714/2009) states that Transmission System Operators (TSOs) shall establish regional cooperation within ENTSO-E and shall publish regional investment plans every two years. TSOs may take investment decisions based on regional investment plans. Article 48 further states that ENTSO-E shall publish a non-binding, community-wide, Ten-Year Network Development Plan, built on national investment plans and taking into account

regional investment plans and the reasonable needs of all system users, and shall identify investment gaps.

In addition, the TYNDP package complies with Regulation (EU) N° 347/2013, which defines new European governance and organisational structures that shall promote transmission grid development.

## 2.3 Scope of the report

Regional Investment Plans are based on pan-European market study results combined with European and/or regional network studies. They present the current situation of the region as well as expected future regional challenges, considering 2030 and 2040 time horizons. To illustrate circumstances that are particularly relevant to each region, available regional sensitivities and other available studies are included in the Regional Investment Plans. The operational functioning of the regional system and associated future challenges may also be addressed.

As one of the solutions to future challenges, the TYNDP project has performed market and network studies for National Trend scenarios in the mid-term 2030 and long-term 2040 time horizons, to identify investment needs such as cross-border capacity increases and related necessary reinforcements of the internal grid, which can help mitigate these challenges.

In addition to this, the Regional Investment Plans present the preliminary list of regional projects from the TYNDP 2020 project collection and proposals for further projects as a result of IoSN analyses.

The approach followed by the regional investment plans is summarised in Figure 2.3.



Figure 2-3: Mitigating future challenges - TYNDP methodology

The current document comprises seven chapters with detailed information at the regional level:

- Chapter 1 presents the key messages about the region
- Chapter 2 sets out, in detail, the general and legal basis of the TYNDP and regional investment plans and provides a short summary of the general methodology used by all ENTSO-E regions
- Chapter 3 covers a general description of the present situation of the region. The region's future challenges are also presented, when describing the evolution of generation and demand profiles in the 2030 and 2040 horizons, but considering a grid as expected by the 2020 and 2025 horizons. This chapter also includes links to respective National Development Plans (NDPs) of the countries of the region

## REGIONAL INVESTMENT PLAN 2020 – CONTINENTAL CENTRAL SOUTH

- Chapter 4 includes an overview of regional needs in terms of capacity increases and the main results from market and network perspectives
- Chapter 5 is dedicated to additional analyses conducted inside the regional group or by external parties outside the core TYNDP process
- Chapter 6 contains the list of projects proposed by promoters in the region at the Pan-European level, as well as important regional projects that are not part of the European TYNDP process

The Appendix includes the abbreviations and terminology used in the whole report as well as additional content and detailed results.

The actual Regional Investment Plan does not include the Cost-Benefit Analysis (CBA) based assessment of projects. These analyses will be developed in a second step and presented in the final TYNDP 2020 package.

## 2.4 General methodology

The Regional Investment Plans build on the results of, so-called ‘Identification of System Needs’, studies conducted by a European team of market and network experts originating from ENTSO-E’s System Development Committee. The results of these studies have been discussed and, in some cases, extended with additional regional studies performed by the regional groups, to ensure all relevant aspects in the regions are covered.

The aim of the Identification of System Needs is to identify investment needs in the mid-and long-term time horizons (2030 and 2040), in a coordinated pan-European manner that also builds on the expertise of the grid planners of all TSOs.

A more detailed description of this methodology is available in the report [‘Completing the map - Power system needs in 2030 and 2040’](#).

## 2.5 Introduction to the region



The Continental Central South Regional Group (CCS) under the scope of the ENTSO-E System. Development Committee is among the six regional groups for grid planning and system development tasks. Member States belonging to each group are shown in Figure 2-4 below. The CCS region comprises six countries: Austria, France, Germany, Italy, Slovenia and Switzerland. The countries belonging to the CCS perimeter along with their respective TSO representatives are presented below.



Country	Company/TSO
Austria	APG <sup>5</sup>
France	RTE
Germany	Amprion, Tennet TSO GmbH, TransnetBW
Italy	Terna
Slovenia	ELES
Switzerland	Swissgrid

Figure 2-4: Regional group membership

In addition, due to its high-grade meshed transmission system, the CCS region has a relatively coherent interaction characteristic on the electricity transmission level between countries of the region and their neighbours throughout the entire perimeter. However, in the central-eastern part of the region - particularly in peripheral areas - transmission infrastructure is currently less developed, leading to more regional limitations of power transits.

Boundaries are present not only on the borders between different countries, but also internally in some countries where they affect the market structure, such as in IT, where the day-ahead energy market is split into six different bidding zones. This is due to internal congestion on the south to north axis and between the main islands and the Italian peninsula, as illustrated in the following figure.

---

<sup>5</sup> APG also represents VUEN in RG CCS



Figure 2-5: Italian market areas

The CCS region's main boundaries are illustrated in Figure 2-6 below. They should be considered as infrastructural obstacles to the full exploitation of generation resources within the electricity market, the integration of renewable energy sources, and the achievement of current security conditions under future scenarios.




Figure 2-6: Boundaries of the CCS perimeter

In this respect, one of the main barriers to power exchanges in the region is the integration of the Italian Peninsula. This implies a need to further develop transmission capacity at the North-Italian boundary in order to exploit new generation, located primarily in the north of DE and FR (wind) and in the south of IT (wind and photovoltaic). This will enable wider power exchanges and make it possible to integrate new generation and pump storage capacity located in the Alps region.

Furthermore, additional needs are linked to new interconnections between Italy and North Africa and between Italy and Montenegro, to increase pan-European market integration, RES usage and system security. In addition, interconnecting the main islands of Sicily, Sardinia and Corsica with the mainland is of major relevance for SoS and market integration within the European system.

## 2.6 Evolution since the RegIP 2017

RegIP 2020 has developed significantly since RegIP 2017. This is due to both the rapidly changing energy economy and regulatory framework conditions, and to improvements in methods.

One of the core tasks of RegIP is the development planning of concrete projects based on the given scenarios and results of the IoSN process. Another task is regional coordination of general grid development planning taking into account all TYNDP projects and projects of regional relevance, in the region. Only the combination of European-wide, regional and national grid development planning will enable the development of a transmission network that can master the challenges of the future energy system. For this reason, Table 2.1 below shows the development of projects in the region since TYNDP 2020.

Comparing the speed of development in the area of generation and consumption, (see Chapter 3.1.2) with the progress of grid expansion projects, it becomes clear that this is a two-speed development. The expected commissioning dates of most projects are often postponed into the future. In addition to existing projects, new projects are also being identified (see Chapter 4) to meet the future needs of the system. The need to accelerate grid expansion caused by the evolution of the energy system is a challenge that every TSO in the region is facing.

Table 2-1: Key Projects in the CCS region included in TYNDP 2020 - evolution since TYNDP 2018

Project Id	Project Name	Project included in TYNDP 2018?	Project submitted to TYNDP 2020?	Promoter	TYNDP 2018		TYNDP 2020	
					Expected Commissioning Year	Status	Expected Commissioning Year	Status
21	Italy-France	yes	No (expected commissioning date in 2021)	RTE; TERNA	2019	Under Construction	-	-
26	Reschenpass Interconnector Project	yes	yes	APG; TERNA	2021	In Permitting	2022/2023	Under Construction
28	Italy-Montenegro	yes	yes	CGES;TERNA	2026	Under Construction	2026	Under Construction
29	Italy-Tunisia	yes	yes	TERNA; STEG	2025	In Permitting	2027	In Permitting
31	Italy-Switzerland	yes	No (project under review)	SWISSGRID; TERNA	2025	In Permitting		
33	Central Northern Italy	yes	yes	TERNA	2022	In Permitting	2026	In Permitting
47	Westtirol - Vöhringen	yes	yes	AMPRION; APG	2024	Planned, but not yet Permitting	2026	Planned, but not yet Permitting
127	Central Southern Italy	yes	yes	TERNA	2022	In Permitting	2024	In Permitting
132	HVDC Line A-North	yes	yes	AMPRION	2025	Planned, but not yet permitting	2025	In Permitting
150	Italy-Slovenia	yes	yes	TERNA;ELES	2025	In permitting (IT side) Under consideration (SI side)	2028 (or later in accordance with implications of the study phase on the Slovenian side)	In Permitting (IT side) Under Consideration (SI side)
164	N-S Eastern DE central section	yes	yes	TENNET-DE	2027	In Permitting	2030	-
174	Greenconnector	yes	yes	WORLDENERGY SA	2022	In Permitting	2024	In Permitting
186	East of Austria	yes	yes	APG	2021	In Permitting	2022	Under Construction
187	St. Peter (AT) - Pleinting (DE)	yes	yes	APG; TENNET-DE	2024	In Permitting	2028	In Permitting
207	Reinforcement Northwestern DE	yes	yes	TENNET-DE	2026	In Permitting	-	-
					2021	In Permitting	2023	Under Construction



					2022	Planned, but not yet Permitting	-	-
					-	-	2020	Under Construction
208	N-S Western DE_section North_1	yes	yes	AMPRION; TENNET-DE	2021	In Permitting	2023	Under Construction
210	Wurmlach (AT) - Somplago (IT) interconnection	yes	yes	ALPE ADRIA ENERGIA SRL	2021	In Permitting	2023	In Permitting
228	Muhlbach - Eichstetten	yes	yes	RTE; TRANSNETBW; AMPRION	2025	Planned, but not yet Permitting	2025	Planned, but not yet Permitting
231	Concept project Germany-Switzerland	yes	yes, renamed Beznau-Tiengen	SWISSGRID; TRANSNETBW; AMPRION	2030	Under Consideration	2030	Under Consideration
					2034	Under Consideration	-	-
235	HVDC Brunsbüttel/Wilster to Großgartach/Grafenrheinfeld	yes	yes	TENNET-DE; TRANSNETBW	2025	In Permitting	2026	In Permitting
244	Vigy - Uchtelfangen area	yes	yes	AMPRION; RTE	2027	Planned, but not yet Permitting	2028	Planned, but not yet Permitting
250	Merchant line "Castasegna (CH) - Mese (IT)"	yes	yes	MERA SRL (a 100% subsidiary of REPOWER AG)	2021	In Permitting	2024	In Permitting
253	Upstream reinforcement in France to increase FR-CH capacity	yes	yes	RTE	2031	Under Consideration	2031	Under Consideration
254	Ultrahet	yes	yes	AMPRION; TRANSNETBW	2021	In Permitting	2024	In Permitting
258	Westcoast line	yes	yes	TENNET-DE	2019	In Permitting	2022	Under Construction
263	Lake Constance East	yes	yes	SWISSGRID; VUEN	2035	Under Consideration	2035	Under Consideration

					2035	Under Consideration	2035	Under Consideration
264	Swiss Roof I	yes	yes	SWISSGRID	2025	In Permitting	2029	In Permitting
					2021	Under Construction	2022	Under Construction
					2025	In Permitting	2027	In Permitting
					2030	In Permitting	2035	In Permitting
265	Tessin	yes	yes	SWISSGRID	2035	Planned, but not yet Permitting	2035	Planned, but not yet Permitting
		yes	yes	SWISSGRID	-	-	2035	Planned, but not yet Permitting
266	Swiss Ellipse I	yes	yes	SWISSGRID	2021	In Permitting	2027	In Permitting
							2022	Under Construction
					2024	Planned, but not yet Permitting	-	-
					2024	In Permitting	2029	In permitting
283	TuNur	yes	yes	TUNUR LIMITED	2025	In Permitting	2026	Under Consideration
299	SACOI3	yes	yes	TERNA; EDF	2023	In Permitting	2024	In Permitting
312	St. Peter - Tauern (AT internal)	yes	yes	APG	2022	In Permitting	2024	Under Construction
313	Isar/Altheim/Ottenhofen (DE) - St. Peter (AT)	yes	yes	TENNET-DE; APG	2021	In Permitting	2023	In Permitting
322	Wullenstetten - Border Area (DE-AT)	yes	yes	AMPRION; VUEN	2020	In Permitting	2025	In Permitting
					2030	Planned, but not yet Permitting	-	-
323	Dekani (SI) - Zaule (IT) interconnection	yes	yes	ADRIA LINK SRL; E3 D.O.O.; HSE D.O.O.	2020	In Permitting	2021	In Permitting
324	Redipuglia (IT) - Vrtojba (SI) interconnection	yes	yes	ADRIA LINK SRL, E3 D.O.O.; HSE D.O.O.	2020	In Permitting	2021	In Permitting
325	AT, SI, IT - South-East Alps Project	yes	yes, renamed Obersielach-Podlog	APG; ELES	2035-2040	Under Consideration	2034	Under Consideration

<b>333</b>	PST Foretaille	yes	yes	SWISSGRID	2031	Under Consideration	2031	Under Consideration
<b>336</b>	Prati (IT) - Steinach (AT)	yes	yes	TERNA; TINETZ	2019	Under Construction	2019	Under Construction
<b>338</b>	Adriatic HVDC link	yes	yes	TERNA	2027	Under Consideration	2030	Planned, but not yet Permitting
<b>339</b>	Italian HVDC tri-terminal link	yes	yes	TERNA	2027	Under Consideration	2025	Planned, but not yet Permitting
<b>375</b>	Lienz (AT) - Veneto region (IT) 220 kV	yes	yes	TERNA; APG	2024	In Permitting	2026	Planned, but not yet Permitting
<b>1034</b>	HVCD corridor from Northern Germany to Western Germany	NO	New in TYNDP 2020	AMPRION; TENNET-DE	-	-	2030	Planned, but not yet Permitting
<b>1052</b>	Lienz (AT) - Obersielach (AT)	NO	New in TYNDP 2020	APG	-	-	2030	Planned, but not yet Permitting
<b>1054</b>	Westtirol (AT) - Zell/Ziller (AT)	NO	New in TYNDP 2020	APG	-	-	2025	Planned, but not yet Permitting
<b>1057</b>	HVDC CentraLink	NO	New in TYNDP 2020	TRANSNET	-	-	2030	Under Consideration
<b>1058</b>	HVDC Interconnector (DE-CH)	NO	New in TYNDP 2020	TRANSNET	-	-	2040	Under Consideration
<b>1059</b>	Southern Italy	NO	New in TYNDP 2020	TERNA	-	-	2030	In Permitting

### 3 REGIONAL CONTEXT

The CCS region is located in the centre of Europe. It is characterised by a rather strongly meshed grid that connects the RES at the edges of the region, with the primarily central load centres, and also provides a connection to the neighbouring regions. Consequently, wide area load flows across Europe can be observed. These are highly dependent on the situation in the whole of Europe and show various characteristics. In particular, climatic parameters such as temperature and rainfall, such as low water levels and flooding, have a significant influence on such flows. In this context, a potent grid has to be available in the CCS region in order to avoid critical grid situations.

In recent years, the entire region has undergone fundamental transformation. In particular, the generation mix has changed significantly. Large scale Offshore and onshore wind power plants were developed in the northern part of the region and the increase of installed PV took place primarily in the southern part of DE and in IT. In addition, baseload power plants such as nuclear or coal are being continually reduced, due to governmental decisions/environmental reasons and market effects.




Figure 3-1: RG CCS and the development of RES

This has led to increasingly volatile production, which has fundamentally changed the characteristic temporal behaviour of the entire generation mix as well as the geographical distances between generation and demand. The speed of change is also increasing.

Putting this rather fast transition of generation capacity in relation with the relatively slow development of transmission infrastructure, a gap between transmission demand and transmission capacity is appearing. Therefore, an extensive analysis has to be conducted to provide the right measures, in the right time, to mitigate future challenges.

Regarding generation assumptions in France, it should be noted that the scenarios of the TYNDP corresponded to the country's rapid pace of nuclear decommissioning, in line with a target of reducing nuclear power's share of the French energy mix to 50% by 2025. In accordance with the last French energy law, 'PPE: Programmation Pluriannuelle de l'Energie', current scenarios correspond to a slower pace of nuclear decommissioning in France with an updated target of 50% by 2035.



Similarly for Italy the main scenario assumptions made in the 2030 and 2040 time horizons take into account the national coal phase out target.

### **3.1 Present situation**

Concerning annual generation in CCS countries, the main contributions covering demand varies from country to country. In France this is from nuclear generation, in Austria it is Hydro and conventional generation while in Switzerland it is from both hydro and nuclear generation. Meanwhile in Slovenia nuclear, thermal and hydro generation are the main contributors, while in Italy it is gas and hydro.

In the German power system conventional thermal generation still has an important role, although the effects of energy transition are already visible. The installed capacities of renewable energy sources account for approximately half of the installed generation capacity.

All this generation offers the potential for export within many CCS countries. In particular, France has the greatest surplus in generation in relation to local demand. Conversely, Italy has the greatest deficit in generation with respect to its local demand.

#### **3.1.1 Transmission grid**

In accordance with the previously given statements, it should be repeated that the transmission grid in the region is rather meshed when compared to the rest of Europe. Consequently, this has led to insufficient or barely adequate transfer capacities and therefore, setting the fulfilment of these transfer capacities' increase is an imperative before planned market integration can be facilitated. This can be clearly seen if the map showing the interconnected network of the CCS region is observed, updated to 2018. This map is provided in Fig. 3-2, where certain voltage levels are marked with distinctive colours (blue - 750kV AC, red - 400kV AC, yellow - 330kV AC, green - 220kV AC, purple - HVDC links)




Figure 3-2: Interconnected network of the region - 2018

It should be noted that the previous figure does not represent the most updated snapshot of the region. Some additional links have come into operation since 2018, such as the first high-voltage, direct current (HVDC) pole of the Italy-Montenegro interconnection that has, since the end of 2019, has made available a 600MW bridge with the Balkans.

For clearer insight into the potential that the region's interconnected system possesses regarding the energy transit, the NTC values (in MW) in the region, taken for the year 2018, are provided in the map in Fig. 3-3. For the sake of clarity, it should be explained that the blue arrows on the enclosed map simply symbolise two different directions in which the energy can be transferred across a selected border.




Figure 3-3: Current NTCs<sup>6</sup> in the region

### 3.1.2 Power generation, consumption and exchange

The overall increase of installed generation capacity compared with the constant maximum consumption hints at power plant the usage. RES infeed is dependent on the weather and runs as long as conditions allow. The rest of the demand is supplied by conventional generation. However, this conventional generation share is getting smaller and smaller and is being replaced by RES generation - as is evident in Figure 3-4 - and is triggering economic problems for the respective power plant operators. The progressive mothballing and decommissions of those generation units creates a risk as they are important for system stability and safety.

<sup>6</sup> on the IT-SI border in the SI→ IT direction, according to D-2 calculation, the NTC value could be higher (up to 808MW) during a limited number of hours




Figure 3-4: Installed generation capacities by fuel type and maximum consumption in the region in 2010 and 2018 [GW]

In the following figures, another very important aspect of the energy transition, with potentially huge consequence for the transmission grid can be observed. As the share of RES installed capacity increases strongly, the energy gained by these capacities has a lower share. This is caused by the lower factor of full load hours produced by RES due to limited natural supply (Figure 3-5).

In other words, to produce the same amount of energy by RES through wind and solar, much more installed capacity is necessary than that required by run-of-river or conventional power plants. Conventional power plants and storage are necessary to balance the fluctuations of RES infeed. Therefore, the transmission system has to be designed in a much more flexible manner than it was in the past. It has to handle a high amount of RES infeed as well as the infeed of conventional power plants to ensure SoS. Therefore, the energy transition on its own, without even considering load growth should be a trigger for additional transport capacities and a significant reinforcement of the grid.






Figure 3-5: Annual generation by fuel type and annual consumption in the region in 2010 and 2018 [TWh]

In addition, due to RES generation's increased share, transmitted energy has also increased. This fact is depicted below and can be observed particularly on the borders of FR–IT, DE–AT and CH–IT. A graphical illustration of this is shown in Figure 3-6, where it is obvious that on all borders, the physical exchanged energy between the countries was significantly lower in 2010 than in 2018.




Figure 3-6: Cross-border physical energy flows [GWh] in the region in 2010 and 2018

### 3.1.3 Grid constraints

Due to its high-grade meshed transmission system, the CCS region has a relatively coherent interaction characteristic on the electricity transmission level between countries of the region, and their neighbours throughout the entire perimeter. However, in the central-eastern part of the region, particularly in peripheral areas, transmission infrastructure is currently less developed, which leads to regional limitations of power transits.

Boundaries are present not only on the borders between different countries, but also internally in some countries where they affect the market structure, such as in IT, where the day-ahead energy market is split into different bidding zones. This is due to internal congestions on the south to north axis and between the main islands and the Italian peninsula.

The CCS region's main boundaries are illustrated in Figure 3-7 below. They should be intended as infrastructural obstacles to the full exploitation of generation resources within the electricity market,

the integration of renewable energy sources, and the achievement of security conditions currently and under future scenarios. The blue arrows represent the main flows occurring on the main boundaries within the region.



Figure 3-7: Main boundaries of the CCS region

It can therefore be observed that one of the main barriers to power exchanges in the region is the integration of the Italian Peninsula. This implies a need to further develop transmission capacity at the North-Italian boundary in order to exploit new generation, located primarily in the north of DE and FR (wind), in the south of IT (wind and photovoltaic) and in CH (hydro and photovoltaic). This will enable wider power exchanges, and make it possible to integrate new generation and pump storage capacity located in the Alps region.

Furthermore, additional needs are linked to new interconnections between Italy and North Africa and between Italy and Montenegro, to increase pan-European market integration, RES usage and system security. In addition, interconnecting the main islands of Sicily, Sardinia and Corsica with the mainland is of major relevance for SoS and market integration within the European system.

Bearing in mind the key power system trends and the most important boundaries mentioned previously, the CCS region's main drivers for network development have been recalled in this section. The most important drivers are classified and are listed, from this point forward, based on the bulk power flows expected in the typical working conditions of the system, particularly under high RES development circumstances.

### 3.2 Description of the scenarios

The TYNDP 2020 Scenario edition published in June 2020 represents the first step in quantifying the long-term challenges of energy transition on European electricity and gas infrastructure.

The joint work of ENTSO-E and ENTSG, stakeholders as well as more than 80 TSOs, covering more than 35 countries, provided a basis to allow assessment for the European Commission's Projects of Common Interest (PCI) energy list, as ENTSO-E and ENTSG progress to develop their respective TYNDPs. We strongly recommend that readers familiarise themselves with the content included in the [Scenario Report](#) and [visualisation platform](#), as these will provide full transparency on the development and outcomes of the scenarios mentioned in this report.

## Scenario Storylines

The joint scenario building process presents three storylines for TYNDP 2020

**National Trends (NT):** The central policy scenario, based on Member States' National Energy and Climate Plans (NECPs) and on EU climate targets. NT is further compliant with the EU's 2030 Climate and Energy Framework (32% renewables, 32.5% energy efficiency) and the EC's 2050 Long-Term Strategy with an agreed climate target of 80 - 95% CO<sub>2</sub>-reduction compared to 1990 levels.

**Global Ambition (GA):** A full energy scenario in line with the 1.5 degrees Celsius (1.5°C) Paris Agreement target, envisions a future characterised by economic development in centralised generation. Hence, significant cost reductions in emerging technologies such as offshore wind and Power-to-X are led by economies of scale.

**Distributed Energy (DE):** This is a full energy scenario –also compliant with the Paris Agreement's 1.5°C target - that presents a decentralised approach to energy transition. In this storyline, prosumers actively participate in a society driven by small scale decentralised solutions and circular approaches. Both Distributed Energy and Global Ambition reach carbon neutrality by 2050

Figure 3-8: Key parameters of the scenario storylines



**Bottom-Up:** This approach to the scenario building process collects supply and demand data from gas and electricity TSOs.

**Top-Down:** The ‘Top-Down Carbon Budget’ scenario building process is an approach that uses the ‘Bottom-Up’ model information gathered from the Gas and Electricity TSOs. The methodologies are developed in line with a Carbon Budget approach.

**Full energy scenario:** A full energy scenario employs a holistic view of the European energy system, thus capturing all fuel and sectors as well as a full picture of primary energy demand.




Figure 3-9: Key drivers of scenario storylines

### Selective description of electricity results.

**To comply with the 1.5°C target of the Paris Agreement, carbon neutrality must be achieved by 2040 in the electricity sector and by 2050 in all sectors.**

Distributed Energy and Global Ambition scenarios, also referred to as ‘COP 21 Scenarios’, are meant to assess sensible pathways to reach the target set by the Paris Agreement for the COP 21: 1.5°C or at least well below 2°C by the end of the century. For the purpose of the TYNDP scenarios, this target has been translated by ENTSO-E and ENTSG into a carbon budget that stays below +1.5°C at the end of the century with a 66.7% probability.






Figure 3-10: GHG Emissions in TYNDP 2020 Scenarios

**To optimise conversions, the direct use of electricity is an important option resulting in progressive electrification throughout all scenarios**

The scenarios show that higher direct electrification of final-use demand across all sectors results in an increase in the need for electricity generation.

Distributed Energy is the scenario storyline with the highest annual electricity demand, hitting around 4300TWh by 2050. The results show that there is the potential for year-on-year growth for EU28 direct electricity demand. Figure 3-11 provides annual EU-28 electricity demand volumes and associated growth rates for the specified periods.

The growth rates for the storylines show that by 2050, National Trends is centrally positioned in terms of growth between the two more-ambitious top-down scenarios, Distributed Energy and Global Ambition. The main reason for the switch in growth rates is due to the fact that Global Ambition has the strongest levels of energy efficiency, whereas for Distributed Energy, strong electricity demand growth is linked to high electrification from the high uptake of electric vehicles and heat pumps, dominating electrical energy efficiency gains.




Figure 3-11: Direct Electricity Demand per Scenario (EU28)

**In the COP 21 Scenarios, the electricity mix becomes carbon neutral by 2040.**

Across the EU-28, electricity from renewable sources meets up to 64% of power demand in 2030 and 83% in 2040. Variable renewable, such as wind and solar, play a key role in this transition, as their share in the electricity mix grows to over 40% by 2030 and over 60% by 2040.

The remaining renewable capacity consists of biofuels and hydro. All figures stated above exclude Power-to-X use, which is assumed to be entirely from curtailed RES, and newly built renewables that are not grid-connected, and therefore not considered in this representation.

**To move towards a low carbon energy system, significant investment in gas and renewable electricity technologies is required.**

Distributed Energy is the scenario with the highest investment in generation capacity, driven primarily by the highest level of electrical demand. Distributed Energy primarily focuses on the development of Solar PV. This technology has the lowest load factor and as a result, Solar PV installed capacity will be higher, compared to that of offshore or onshore wind, in meeting the same energy requirement. The scenario shows a larger growth in Onshore Wind after 2030. By then, 14% of electricity is produced from Solar and 30% from wind, 44 % in total. In 2040, 18% is generated from solar and 42% from wind, giving a 60% total. Out of all the three scenarios, this one sees the least amount of electricity produced from nuclear, which is predicted to provide 16% of electricity in 2030 and 10% in 2040.




Figure 3-12 Percentage share of electricity demand covered by RES

Global Ambition has a lower electricity demand, with a general trend of higher nuclear and reduced prices for offshore wind. Consequently, the capacity required for this scenario is the lowest as more energy is produced per MW of installed capacity in offshore wind, and nuclear is used as base load technology providing 19% of energy in 2030 and reducing to 12% in 2040. In 2030, 10% of electricity

is produced from Solar and 32% from wind, making 42% in total. In 2040 13% of the electricity is generated from solar and 45% from wind for a 58% total.

National Trends is the policy-based scenario and delivers variable renewable generation somewhere between the two top down scenarios. In 2030, 12% of electricity is produced from Solar and 30% from wind, giving a 42% total. In 2040 14% of electricity is generated from solar and 42% from wind for a 56% total. A lot of electricity is still produced from nuclear in 2030, 17% reducing to 12% in 2040.

**Shares of coal for electricity generation decrease across all scenarios.** This is due to national policies on phasing out coal, such as those announced by the UK and Italy, or planned by Germany. Coal generation moves from 10% in 2025, to 4-6% in 2030 and negligible amounts in 2040 which represents an almost complete phase out of coal.

**Considerations on other Non-Renewables (primarily smaller scale CHPs) sources are important for decarbonisation.** As it stands, carbon-based fuels are still widely used in CHP plants throughout Europe. This includes oil, lignite, coal and gas. In order to follow the thermal phase out storylines, oil, coal and lignite should be phased out by 2040 and replaced with cleaner energy sources. Gas will contribute to decarbonisation through increased shares of renewable and decarbonised gas.




Figure 3-13: Electricity Capacity mix

## More renewable energy from neighbouring countries

It should be highlighted that the integration of electricity generated by renewable energy sources in EU countries will not, in itself, be sufficient in achieving the EU's climate goals. Therefore, the integration of EU and third country system grids will play an important role.

However, the interaction between the two systems is not robust enough to guarantee such renewable energy exchanges. Therefore, investment in transmission infrastructure between EU countries, particularly Southern EU Member States such as Italy, with third countries such as Tunisia, are potentially an effective means of promoting the EU's external policy objectives, such as energy

transition, integration of renewables, security of supply, as well as regional and local socio-economic welfare, economic cooperation, peace and solidarity.

### Sector Coupling - an enabler for (full) decarbonisation

For ENTSO-E and ENTSG, sector coupling describes the interlinkages between gas and electricity production, and infrastructure. Major processes in this regard are gas-fired power generation, Power-to-Gas (P2G) and hybrid demand technologies. TYNDP 2020 scenarios are dependent on the further development of sector coupling, as without these interlinkages, high or even full energy sector decarbonisation will not be reached.

Assuming a switch from carbon-intensive coal to natural gas in 2025, 150Mt CO<sub>2</sub> could be avoided in power generation. With increasing shares of renewable and decarbonised gases, gas-fired power plants become the main ‘back-up’ for variable RES in the long-term. Distributed Energy even shows a further need for CCS for gas power plants to reach its ambitious target of full decarbonised power generation by 2040.

On the other hand, P2G becomes an enabler for the integration of variable RES and an option to decarbonise the gas supply. Hydrogen and synthetic methane allow for carbon-neutral energy use in the final sectors. Distributed Energy is the scenario with the highest need for P2G, requiring about 1500TWh of power generation per year, with 493GW of capacities for wind and solar in 2040 to produce renewable gas. Sector coupling in National Trends, with the assumption that P2G generation is limited to ‘curtailed electricity’, considers 12TWh of power generation with 22GW of P2G to produce renewable gas.




Figure 3-14: Capacities for hydrogen production




Figure 3-15: Power-to-Gas generation mix

### 3.3 Regional scenario towards 2040

Given the assumption in the previous paragraphs, it can be observed that generally, in the CCS region, sharp increases in wind and solar capacity development are foreseen in all countries, in particular 140GW of wind and 150GW of PV in DE and 100GW of wind and 70GW of PV in FR. No new significant nuclear capacity developments are expected in the CCS. In these scenarios the highest renewable generation capacity increase in 2040, compared to 2025, is expected in IT by around 65-70 GW and the developments are being seen primarily in solar and wind generation.

Furthermore, the following scenarios at the 2040 time point have to be highlighted:




Figure 3-16: CCS region installed generation capacities in NT 2025 scenario






Figure 3-17: CCS region installed generation capacities in NT 2030 scenario




Figure 3-18: CCS region installed generation capacities in NT 2040 scenario

Analysing the graph below, we can see that the highest capacity increase from solar generation, for the Distributed Energy scenario, is between 2030 and 2040 in DE. In the region generally, huge solar capacity development is foreseen in all countries. Wind generation capacity will significantly increase between 2025-2040 in all the CCS region countries.

From 2025 there is no more nuclear generation in DE and no new significant nuclear capacity development is expected in the CCS. A significant decrease of nuclear is also foreseen in FR and CH, up to 2040. A relevant decrease of hard coal power plants is also expected in DE and in IT.

Between 2025-2040, the evolution of hydro power should remain stable in all the countries of the region, although that evolution is difficult to predict.




Figure 3-19: CCS region installed generation capacities in DE 2030 scenario




Figure 3-20: CCS region installed generation capacities in DE 2040 scenario




Figure 3-21: CCS region installed generation capacities in GA 2030 scenario




Figure 3-22: CCS region installed generation capacities in GA 2040 scenario

Given the strong increase in household-level generated solar power, the Distributed Energy scenario, foresees high solar and wind development in all countries in the region.

Looking at the picture below, it can be observed that the CCS region is primarily composed of exporting countries, such as FR and DE, but with some exceptions, such as Italy, that need high levels of importing energy till 2040. In order to guarantee these power exchanges, further transmission capacity development will be necessary.



Figure 3-23a: Importer versus Exporter market zones in the CCS region in NT 2025 scenario




Figure 3-23.b: Importer versus Exporter market zones in the CCS region in NT 2030 scenario




Figure 3-23.c: Importer versus Exporter market zones in the CCS region in NT 2040 scenario

A more detailed description of the scenario creation is available in the TYNDP 2020 Scenario Report<sup>7</sup>.

<sup>7</sup> TYNDP 2020 Scenario Report: <https://tyndp.entsoe.eu/>

### 3.4 Future challenges in the region

The European Study Teams have carried out simulations of all three 2040 and 2030 scenarios - National Trend, Global Ambition and Distributed Energy - with the expected grid of 2025 and 2020 respectively. Even if these simulations were somewhat artificial - in the real world, the market and grid develop in close interaction with each other - the study revealed expected needs that the power system will have to face, if the grid does not evolve beyond 2025, such as:

- insufficient integration of renewables (high amounts of curtailed energy) and high CO<sub>2</sub> emissions;
- high price differences between market areas;
- high flexibility need; and
- bottlenecks between market areas and inside these areas.

In addition to the above-mentioned problems, operational security issues are present in areas where the network is less meshed, such as the eastern part of the northern Italian border, particularly the internal Italian grid involving the main islands, and the Adriatic backbone.

Such needs show that all the projects planned up to 2025 are of high importance, but they cannot face all the challenges foreseen in the upcoming years. More in-detailed, identified needs can be primarily addressed through investment in transmission infrastructure and, regarding the mid-term horizon, the confirmed planned projects of TYNDP 2018.

The charts below describe the regional challenges identified by the simulations as mentioned above. They show the average results and ranges of simulations of three different climate years for all three long-term 2040 scenarios. All simulations have been carried out by several market models.

Given the above, the following chapters will present future challenges in the region for both the 2030 and 2040 time horizons.

#### 3.4.1 Market simulations 2030 and 2040 scenarios

##### Annual Country balance

The analyses of the 2030 scenarios against the 2020 transmission grid show, in Figure 3-24, the net annual 2030 scenarios country balance, where the transmission grid does not evolve beyond 2020. The bars highlight the average 2030 scenarios values for each country.

On average IT, DE and CH result as importing Countries with respectively approximately 60 TWh, 3TWh and 1TWh of imported energy. AT, SI, FR, primarily export energy, with respective values of approximately 8TWh, 2TWh, and 83TWh






Figure 3-24: Import versus Export country level in the CCS region for 2030 scenarios with 2020 grid

The 2040 scenarios analyses against the 2025 transmission show, in Figure 3-25, the net annual 2040 scenarios country balance, where the transmission grid does not evolve beyond 2025. The bars highlight the average 2040 scenarios values for each country.

The outcomes confirm, as shown in the 2030 scenarios analyses, Italy as a big importer country with approximately 40TWh of imported energy and Germany an importer with about 3TWh of imported energy. AT, SI, FR and CH primarily export energy, with respective values of approximately 18TWh, 3TWh, 62TWh and 8TWh.




Figure 3-25: Import versus Export country level in the CCS region for 2040 scenarios with 2025 grid

### **Integration of renewable energy sources.**

The goal of renewable energy integration is to improve the electric grid's sustainability, while also reducing carbon emissions and other air pollutant emissions, through the increased use of renewable energy. The CCS regional group, due to its geographical position and configuration, presents the availability of several renewable sources (primarily sun, wind and water) and has a key role in the transition to a more sustainable system.

According to the analyses, the curtailed energy - in the countries across the region - presents remarkable values, primarily in Germany and Italy, where the amount of energy produced from renewable sources that cannot be fed into the grid, is expected to be of several TWh.

Figure 3-27 shows the curtailed renewable energy in the 2040 (and 2030) scenarios if the transmission grid does not evolve beyond 2025 (and 2020).

In DE, energy production has already been dominated by RES. With the country facing a further increase of RES generation; it is of utter importance to limit the impact of curtailed energy. To do so, it is necessary to ensure firm connections to flexible production areas and storage units - eg in the Alps.

In Italy, the maximum value of curtailed energy is up to 8TWh in the 2040 scenarios (and higher than 3TWh in the 2030 scenarios), primarily concentrated in the south and in the islands. RES integration is of primary importance for the country and the values resulting from market analyses clearly demonstrate the need for additional transmission infrastructure to implement the transition towards sustainable

energy production. It is worth highlighting that these results are based on a simplified model that does not consider all local congestions on the internal network interested by the connection of new RES capacity.

Investment in batteries can also enable RES integration, but it is important to highlight that even if scenarios include a non-negligible amount of batteries, the analyses show high values of curtailed energy.

Therefore, investing in transmission infrastructure is essential for increasing the amount of RES integration, particularly in Germany, thanks to the possibility of sharing the resources present in one area and exceeding the area's load in neighbouring zones. The need to improve RES integration in the region can be largely addressed in the mid-term, thanks to the confirmed planned TYNDP 2018 projects, even if according to additional analyses and the expert view of the TSOs of the region, these projects are not completely sufficient in integrating all the renewable energy foreseen in the long-term scenarios.

In particular, planned internal lines in each of the concerned countries - and links between mainland and major islands such as Corsica, Sardinia and Sicily - are important to integrating variable energy sources. In addition, interconnections on the northern Italian boundary will make it possible to integrate new generation, primarily located in the north of DE and FR (wind), in IT (wind and photovoltaic) and in East-Central Europe, and to enable wider power exchanges to integrate RES generation and pump storage capacity located in the Alps region (CH and AT). Links between IT and North Africa and between IT and Montenegro, interconnecting areas affected by over-generation problems, will also contribute to RES usage.




Figure 3-26: Curtailed energy in the CCS region for 2030 scenarios with 2020 grid




Figure 3-27: Curtailed energy in the CCS region for 2040 scenarios with 2025 grid

CO<sub>2</sub> emissions are closely connected to RES integration and Figures 3-28 and 3-29 below present the CO<sub>2</sub> emissions in megatonnes (Mt) for both the 2030 and 2040 scenarios if the transmission grid does not respectively evolve beyond 2020 and 2025. The bars highlight the average values for each country in all scenarios analysed.

The highest CO<sub>2</sub> emissions in the region are in DE and IT, primarily due to higher usage of thermal generation, while the other countries present lower but not negligible emission values. Considering also the high curtailment of renewable generation presented above, there is a strong driver for investment in the transmission system.




Figure 3-28: CO2 emissions in the CCS region for 2030 scenarios with 2020 grid




Figure 3-29: CO2 emissions in the CCS region for 2040 scenarios with 2025 grid

### **Market integration in the Region**

Price difference values between different market areas - higher than a few euros - demonstrate poor market integration and hint at the necessity to invest in additional interconnections. As reported in the *Report of the Commission Expert Group on electricity interconnection targets*<sup>8</sup>, “A well-integrated energy market is considered a fundamental prerequisite to achieve the EU energy and climate objectives in a cost-effective way. Interconnectors are therefore a vital physical component of Europe's energy transition and offer capacity for energy trade”.

Currently, the northern Italian border is one of the most congested in Europe, due to the high market price differential between Italy and its neighbouring markets. Analyses performed confirm that market integration is a main driver for grid development in the region.

Figure 3-30 shows the average hourly price differences, across borders in the Region in 2030 scenarios if the transmission grid doesn't evolve beyond 2020. The bars highlight the average values for each country in all 2030 scenarios.

The average price differences between countries are significantly high, with almost all values >10 €/MWh. The highest price differences are found in borders involving the Italian Peninsula which, given its geographical characteristics, is one of the most isolated systems in Europe.

<sup>8</sup>[https://ec.europa.eu/energy/sites/ener/files/documents/report\\_of\\_the\\_commission\\_expert\\_group\\_on\\_electricity\\_interconnection\\_targets.pdf](https://ec.europa.eu/energy/sites/ener/files/documents/report_of_the_commission_expert_group_on_electricity_interconnection_targets.pdf)



In particular, Italy sees very high price differences - in the range of €6-24/MWh - with neighbouring countries on its northern boundary (AT, CH, DE, SI), with the maximum value on the Italian-French border, where the average price difference is about €24/MWh. The border between IT and North Africa also presents a remarkable price difference of about €13/MWh. Moreover, the analyses performed highlight price spreads among the six Italian zones, particularly between ITcn-ITsar and ITcn-ITcs.

The development of the common electricity market and the full integration of peripheral areas, by removing present and future bottlenecks, are essential for achieving the Internal Energy Market (IEM) and are necessary from improving the competitiveness of countries. Hence, the foreseen price-spreads in the region, if the grid does not evolve beyond 2020, highlight the presence of barriers to power flows, leading to inefficiency and scarce competitiveness in countries where the cost of energy is higher.

The need to improve market integration in the region can be primarily addressed in the mid-term, thanks to the confirmed planned projects of TYNDP 2018 even if, according to additional analyses and the expert view of the TSOs of the region, these projects are not completely sufficient to satisfy complete market integration in the long-term scenarios.

Planned interconnections on the northern Italian boundary, links with North Africa and the Balkans, and links between mainland and major islands such as Corsica, Sardinia and Sicily, are of primary importance in integrating the markets of peripheral areas and/or different regions. For example, Corsican power plants are less efficient and more expensive than Italian plants, whereas interconnections with North Africa and the Balkans will foster the integration of the pan-European market.




Figure 3-30: Average hourly price differences for National Trends 2030 with 2020 grid - bidding zones

Looking at results with 2040 scenarios in the figures below, average hourly price differences across the borders in the Region - in 2040 scenarios if the transmission grid doesn't evolve beyond 2025 - are shown. The bars highlight the average values for each country in all 2040 scenarios.

The average price differences between countries are significantly high, with almost all the values >25-€30/MWh. The highest price differences are found again in borders involving the Italian Peninsula that, also given its geographical characteristics, is one of the most isolated systems in Europe.

In particular, Italy sees very high price differences - in the range of €10-55/MWh) with neighbouring countries on the northern boundary (AT, CH, SI, FR), with the maximum value on the ITn-AT, where the average price difference is about €55/MWh. The border between IT and North Africa also presents a remarkable marginal cost difference of about €50/MWh. Moreover, the analyses performed, highlight price spreads among the six Italian zones, particularly between ITcn-ITsar and ITcn-ITcs.



Figure 3-31: Average hourly price differences for National Trends 2040 with 2025 grid - bidding zones

Figure 3-32 and 3-33 below show the average annual marginal costs considering 2030 and 2040 scenarios if the transmission grid doesn't evolve beyond 2020 and 2025 respectively.

Looking at long term 2030 scenarios, the region is characterised by notable price differences by simply considering the average price over €40/MWh. These values give a general overview on the costs of energy production in the countries of the region. In 2030 scenarios CH and FR present the lowest prices - approximately €25-28/MWh; SI and IT present the maximum prices - approximately €45/MWh and €48/MWh respectively; whereas in AT and CH similar prices are found - approximately €40/MWh.




Figure 3-32: Marginal costs in the CCS region for National Trends 2030 with 2020 grid

Looking at very long term 2040 scenarios, the average price is much higher at over €55/MWh. These values give a general overview on the costs of energy production in the countries of the region. In the 2040 scenarios FR and CH present the lowest prices - approximately €30-40/MWh); DE and AT present the maximum prices - approximately €70/MWh); whereas in IT and SI similar prices are found - respectively €62/MWh and €68MWh).




Figure 3-33: Marginal costs in the CCS region for National Trends 2040 with 2025 grid

### **Main flows on the transmission network**

The map in Figure 3-34 shows overloads on cross-border lines as a summary over the analysed scenario. In general, the interconnections are challenged in the 2030 scenarios by larger and more volatile flows, due to longer-distance flows crossing Europe caused by intermittent renewable generation in different regions.

As is evident, considerable overloads are identified regarding current grid capacities. To cope with future situations based on the expected scenarios, the big exporters, such as FR and DE, have an urgent requirement for grid development. For IT, the same applies, with the additional hurdle of being a peninsula. The project list reflects this need, with several projects presented that include solutions for exactly this challenge. Besides their own plans to increase RES generation and to connect pump storage hydro plants, the countries in the centre, CH and AT, are affected by the massive changes in neighbouring countries. This provides an additional challenge for the flexibility of the projects in coping with a multitude of different load flow situations. The given projects ought to have this flexibility, which will be verified within the elaboration of the TYNDP.

In more detail and concerning the cross-border lines, the Italian northern boundary results overloaded even in N condition. This evidence, considering also the high price spreads between Italy and all its neighbouring countries previously outlined, indicates the need for additional interconnections on the entire Italian northern boundary. This is particularly evident on its eastern borders with Austria and Slovenia, which have low NTC values, to allow power exchanges between the Italian Peninsula and continental Europe, as foreseen in the long-term scenarios. Moreover, congestion and overloads in N condition are also found between the six Italian market zones.

The CCS Countries' internal grids are similarly constrained in all the 2030-2040 scenarios, necessitating several internal reinforcements. DE and FR are the countries with the biggest number of reinforcements needed whereas AT, IT and CH present the need for an important amount of reinforcements and SI is supposed to have the necessity for some reinforcements.




Figure 3-34: Yearly averaged flows [MW] with 2020 grid versus 2030 scenarios

The need to mitigate the region's network bottlenecks and barriers can be significantly addressed in the mid-term thanks to the confirmed planned projects of TYNDP 2018, even if these projects are not completely sufficient in solving network issues in the long-term scenarios. Planned interconnections on the northern Italian boundary will mitigate, for example, bottlenecks on the IT–FR border, whereas the remaining part of the boundary continues to present bottlenecks.

In addition, internal Italian links and interconnections on the other borders of the region (AT–SI, DE–AT, DE–CH, DE–FR, FR–CH) are of primary importance in significantly mitigating bottlenecks.

### 3.4.2 Additional challenges in the Region

#### Dynamic stability of the grid: inertia decrease

As a result of many changes, transmission systems are becoming increasingly complex. Considering long-term planning and the operational context, cross-border interdependency between different European countries, on the one hand, presents a significant challenge for all TSOs. On the other hand, renewable generation technologies are taking the place of conventional ones at the same high frequency as the increasing interconnection between countries.

To cope with the need for balancing those aspects with present transmission systems, it will be necessary to consider more accurately some additional aspects, such as the inertia level for countries related to frequency response. According to the scientific literature, the magnitude of the frequency variation depends on the difference between generation and demand, compared to the size of the electrical system. Specifically, the time required to reduce frequency excursion depends on the system inertia given from rotating machines (generators). The lower the available inertia, the higher the frequency deviation is. With very low inertia, the system could be exposed to very high frequency excursions and even blackouts.

The variability in the power output from RES, which is driven by the variability of the primary energy resource, must be balanced, including forecast output deviations, in order to maintain frequency level.

Residual load ramps exhibit the hourly changes of residual load (demand minus RES). These curves express the response, in MW/hour, that needs to be provided by controllable resources such as generating units and demand and storage, in order to maintain balance between generation and demand. They also provide an additional measure into the challenges of operating a system with reduced amounts of controllable generating units, high flexibility needs in normal operation and a requirement to guarantee the necessary volume of frequency reserves in all timescales for the cases of unforeseen imbalances between active power generation and demand.

The following plots display the duration curves of residual load ramps of the CCS region as the changes of residual load (load - RES), from one hour to the following one, in a synchronous area on a full year. RES includes all RES sources except hydro.






Figure 3-36: Hourly Residual load ramp [MW/h] in all scenarios - Germany




Figure 3-37: Hourly Residual load ramp [MW/h] in all scenarios - Austria




Figure 3-38: Hourly Residual load ramp [MW/h] in all scenarios - Slovenia




Figure 3-39: Hourly Residual load ramp [MW/h] in all scenarios - Switzerland




Figure 3-40: Hourly Residual load ramp [MW/h] in all scenarios - France




Figure 3-41: Hourly Residual load ramp [MW/h] in all scenarios - Italy

To address these issues, mitigation measures are necessary. An increasing level of interconnection between neighbouring areas could be a possible starting point, particularly by using HVDC lines that can guarantee faster frequency response and HVAC lines that allow mutual support between different areas sharing available resources.

### **Interconnection ratio**

The European Council established on 15 and 16 March 2002 the objective of reaching a minimum interconnection ratio of at least 10% of installed generation capacity in every Member State<sup>9</sup>. In the EC's view, the EU energy policy goals and the 2020 and 2030 energy and climate targets will not be achievable without a fully interconnected European electricity grid. A grid with more cross-border interconnections, storage potential and smart grids, to manage demand and ensure a secure energy supply in a system with higher shares of variable renewable energy. Therefore, the gradual construction of the pan-European electricity highways will also be crucial.

In October 2014, the European Council called for the speedy implementation of all the measures to meet the target of achieving by 2020 an interconnection level of at least 10% of their installed electricity production capacity for all Member States.


Concerning the CCS regional group, at present only IT is still unable to meet this target due to its geographical configuration - surrounded by sea and with the Alps on its northern border - implying higher complexity with the realisation of new interconnections. In 2020, despite the realisation of new interconnections, Montenegro and AT, IT is still expected to not meet the 10% objective (see figure below). On the other hand, some countries already meet and far exceed the target interconnection values such as Slovenia, with 84% in 2017.

Further details on the evolution of the interconnection ratios in the region in the long-term up to 2040, and according to the new criteria established by the European Commission Expert Group on electricity interconnection targets, are provided in the Pan-European System Need report ([link](#)).

Interconnection  
target 10% criteria  
2020

**Color code:**

- - Below 10% threshold
- - Above 10% threshold
- - not considered



<sup>9</sup> The COM (2001) 775 establishes that 'all Member States should achieve a level of electricity interconnection equivalent to at least 10% of their installed generation capacity'. This goal was confirmed at the European Council of March 2002 in Barcelona and chosen as an indicator the EU Regulation 347/2013 (annex IV 2.a) The interconnection ratio is obtained as the sum of importing GTCs/total installed generation capacity.

Figure 3-42: Fulfilment of the 10% interconnection target in 2020

Looking at 2030, the EC established a higher level of interconnectivity between Member States, of at least 15% by 2030.

In order to reach the Interconnection target, Many EU Countries will need to further develop their transmission infrastructure. In many cases such as Italy, it has been estimated<sup>10</sup> that the 2030 interconnection target will not be reached if only the current planned projects in TYNDP are considered. In this regard, investment in new transmission projects is essential for those countries that lack adequate transmission capacity.

---

<sup>10</sup> See TYNDP 2018

## 4 REGIONAL SYSTEM NEEDS

This chapter illustrates and explains the results of the regional studies and is divided into three sections. Chapter 4.1 provides the future capacity needs identified during the IoSN process, while chapters 4.2 and 4.3 describe the market and network results that led to choosing these increases.

### 4.1 Future capacity needs

Among the initial stages of the TYNDP 2020 development, the identification of the cross-border transmission capacities that need to be increased until 2040 to fulfil some of the previously listed criteria and drivers was performed, with the grid valid for the 2025 time horizon being taken as reference when conducting this process. A European overview of these increases is presented in the European System Need report, developed simultaneously by ENTSO-E alongside the drafting of this RgIP 2020.

Due to the continuity of the TYNDP process, the mature projects from earlier TYNDP versions have been added directly as a starting point of the analyses and based also on the needs shown in Chapter 3. Starting from this basis, other increases are shown with the need(s) they fulfil according to ‘IoSN methodology’; needs triggered by market integration in a first step by comparing standard costs and socioeconomic welfare (SEW) benefits. Afterwards, and in the event that SoS and/or RES needs are not fulfilled, further transmission capacity increases are identified by analysing the results of market and network simulations.

Based on the results, an additional assessment has been carried out to understand the probability of occurrence of the identified needs, and the concrete feasibility of projects linked to these needs, by considering physical and technical constraints.

The figure below shows the main results of the analyses, but not the only one. Starting from the foreseen 2025 grid towards the 2030 system, and the 2025 grid towards the 2040 system, the provisional values of the additional capacity increases have been identified. The results are presented in the section covering additional capacity increases.

The identified future capacity needs, on the cross-border profiles in the CCS region, could possibly be covered by the future transmission projects - included in the TYNDP 2020 CBA assessment process - or could remain as a necessity for future grid development.

The outcomes of the market and network investigations validated the necessity of the confirmed TYNDP 2018 projects to meet market integration needs, increase the sustainability of the transmission system by integrating more RES generation and improving the security of supply.


In addition, based also on the results of market and network simulations in 2040 scenarios, a few additional projects covering the next few years till 2040, could be developed for the inclusion in the present and/or future TYNDPs, on top of the TYNDP 2018 still confirmed projects. For example, the borders where it could be interesting to investigate new projects are:

- Italy - Austria - where additional projects are currently under study by the concerned TSOs
- Italy - France
- Italy - Greece



With reference to Capacity increase on the Austrian-German border, the identified capacity increase of 2500MW for time horizon 2030 is primarily covered by TYNDP 2020 projects 47 ‘Westtirol (AT) - Vöhringen (DE)’ and 187 ‘St. Peter (AT) - Pleinting (DE)’. These together with project 263 ‘Lake Constance East’ also cover the identified capacity increase of 3200MW for time horizon 2040.

Figure 4-3a below shows that, as far as long term time horizon 2040 is concerned, the highest identified potential investment needs in the CCS region, on top of the 2025 grid, are located on Germany's borders. The Swiss, Austrian, and Italian borders present remarkable capacity needs. More specifically, it can be observed that Italy requires a relevant capacity increase not only on its Northern border - such as IT-FR, IT-CH, and IT-AT - but also with on its borders with Montenegro and Greece. In addition, in 2040 the French border to Switzerland will also require capacity increases.



Looking at Figure 4-3b, it can be seen how expected capacity increase for the CCS region - such as increases on the Italian borders - over the long term time horizon 2040, are needed from 2030. However, it should be noticed that 2030 IoSN analyses provide a more complete view of the other capacity needs increases that will need to be considered. In this regard, the Italian system grid reveals additional capacity increase on its North African<sup>11</sup> border by 2030, as well as on its internal borders.




Figure 4-3.b: Identified capacity increase needs in the NT 2030 scenario

Figures 4-3a and 4-3b present only cross-border transmission capacity increases, as the simulator investigated only borders between countries. However projects and reinforcements internal to the Countries are also important for consistent grid development. Internal investment is a matter of further analysis within the scope of the National Development Plans.

It is worth highlighting that the results presented above do not represent the only needs for further transmission development of the Region. The results are limited as are the IoSN analyses.

<sup>11</sup> Further details are given in following chapters

#### 4.2.1 Further needs investigation for 2030 and 2040 scenarios

The IoSN SEW-based needs-grid is a depiction of the needed effective cross-border transfer capacity increases that are necessary for the cost-optimised operation of the 2030-2040 system. It is important to note that considerations - in terms of system resilience, system security, or other societal benefits - are not included in this analysis. The cost-optimised operation of the 2030-2040 system is a function of the cost estimates for the cross-border capacity increases and generation costs.

While the optimisation process behind this analysis aimed for a robust identification of the cost-optimised system, the inherent complexity of the power system implies that different depictions of the needed cross-border capacity increases, lead to results of practically similar benefits. Figure 4-20 and 4-21 capture, respectively for the 2030 and 2040 system, this effect for those borders where a different SEW-based needs-solution would lead to similar benefits. This would therefore suggest that it is a well-identified need without being part of the IoSN SEW-based needs - these network increases do not constitute an alternative grid solution, as they do not all belong to the same grid solution.

Figure 4-20: Additional network increases included in grid solutions that were only slightly more expensive than the SEW-based Needs 2030.



The indicators that are analysed according to this scheme are:

- System costs
- Curtailed energy
- CO2 Emissions
- Yearly average of marginal cost
- Net annual country balance

In the following analysis, we concentrate on effects in the region and less on the effects in the individual countries. Countries without an effect are not displayed.




Figure 4-4: Reduction of CCS region System costs in the NT 2030 scenario with identified capacity increases (grid with no investment after 2020 and the SEW-based needs-grid for the horizon 2030)




Figure 4-5: Reduction of CCS region System costs in the NT 2040 scenario with identified capacity increases (grid with no investment after 2025 and the SEW-based needs-grid for the horizon 2040)

Thanks to grid expansion, system costs in the region can be reduced both in comparison with grid expansion between 2020 and 2030 and with grid expansion between 2025 and 2040. In the case of IoSN 2030 the system costs are reduced by €422m and in the case of IoSN 2040 even by €1782m. In Italy in particular, network expansion is leading to a considerable reduction in system costs. In Germany, there

is a strong reduction in system costs in the case of IoSN 2040. The higher system costs in France, in the case of IoSN 2030 and the small reduction in the case of 2040, are due to higher production.




Figure 4-6: CCS region curtailed energy in the NT 2030 scenario with identified capacity increases (grid with no investment after 2020 and the SEW-based needs-grid for the horizon 2030)




Figure 4-7: CCS region curtailed energy in the NT 2040 scenario with identified capacity increases (grid with no investment after 2025 and the SEW-based needs-grid for the horizon 2040)

Thanks to network expansion - driven by significant amounts of curtailed energy - this energy can be reintegrated into the system at low cost. The entire region benefits from this, but the positive effects are particularly marked in Germany. In the case of IoSN 2030, the region integrates 22TWh of lost energy into the system and in the case of IoSN 2040 even 47TWh. This reduction in the case of IoSN 2040 represents more than twice the total energy production of Slovenia.




Figure 4-8: CCS region CO2 emissions in the NT 2030 scenario with identified capacity increases (grid with no investment after 2020 and the SEW-based needs-grid for the horizon 2030)






Figure 4-9: CCS region CO2 emissions in the NT 2040 scenario with identified capacity increases (grid with no investment after 2025 and the SEW-based needs-grid for the horizon 2040)

In both cases, a reduction in CO2 emissions takes place in the region. In the case of IoSN 2030, the reduction of CO2 emissions is 3Mt and in the case of IoSN 2040 the reduction is 7Mt. The rather low values are, on the one hand, because the system already emits very little CO2 and, on the other hand, are due to the positive effects of CO2-free technologies. There is therefore a low replacement of fossil fuels in the region, while the additional energy is exported for pan-European benefit.




Figure 4-10: CCS region Yearly average of marginal cost in the NT 2030 scenario with identified capacity increases (grid with no investment after 2020 and the SEW-based needs-grid for the horizon 2030)




Figure 4-11: CCS region yearly average of marginal cost in the NT 2040 scenario with identified capacity increases (grid with no investment after 2025 and the SEW-based needs-grid for the horizon 2040)

In principle, marginal costs in the region fall in both cases. The strongest effects occur in Germany and Italy, Here the marginal costs fall by more than half in the case of IoSN 2040. This is due to the high amount of low-cost, CO<sub>2</sub>-free energy curtailed in Germany. This naturally leads to positive effects in the marginal costs across the entire region.




Figure 4-12: CCS region net annual country balance in the NT 2030 scenario with identified capacity increases (grid with no investment after 2020 and the SEW-based needs-grid for the horizon 2030)




Figure 4-13: CCS region net annual country balance in the NT 2040 scenario with identified capacity increases (grid with no investment after 2025 and the SEW-based needs-grid for the horizon 2040)

The grid expansion in the case of IoSN 2030 results in an increased export of 39TWh in the region and in the case of IoSN 2040, an increased export of 26TWh of energy. As a rule, the need for imports from Italy and exports from France increases. In both comparisons, Germany changes from an importer to an exporter of energy. There is therefore a significant change in generation behaviour and exchange within the region, with considerable effects outside the region.

### **Main flows on the network with increased transmission capacity**

Chapter 4.1 described future needs within the CCS area. According to the scope and methodology of IoSN, these needs are only located at the borders between countries.

However, it is worth highlighting that the results presented above do not represent the only further transmission development scenario for the Region. The following paragraphs describe further indications of capacity increase in the region, that bring significant and important results, in terms of transmission system development.

Even though internal grid development was not part of the scope of IoSN, the use of zonal methodology allows us to take into account the whole grid, and it was possible to compute the flows also on the internal grids, - on equivalent grid models.

Additional internal reinforcements are needed to make the NT scenario feasible from the network point of view, which implies integrating considerable amounts of additional renewable power generation, and to accommodate not only new power flows profiles, but also higher volumes, both internal and cross-border.

### 4.3.1 2040 horizon

In the following maps, we show the ‘yearly average load’, in other words, the average value of the flows between two zones, compared to the capacity of these inter-zones. A number higher than 1 indicates that on average, the flows between two zones exceeds capacity. This is due to the fact that in IoSN methodology, it was decided to focus on cross-border capacity increases, whereas the capacity of inter-zones inside a country, were considered infinite. This is why the need (see Chapter 4.1) are only cross-border. Nevertheless, thanks to the zonal model, it is possible to understand the flows between the zones of a country.




Figure 4- 16.a: Yearly average load for NT 2040 scenario versus 2025 grid in the CCS region




Figure 4- 16.b: Yearly average load for NT 2040 scenario in CCS region

The Figures above show the remaining internal constraints. Besides cross-border capacities, there is a need to strengthen internal grids - which is partly treated by the implementation of 'standard costs'. The following maps show flows in MW on the network (equivalent grid of zonal model).




Figure 4-17.d: Flows [MW] for NT 2040 scenario

The needs identified in the IoSN SEW-based needs grid, show that flows are going to increase, particularly where we increase the capacity available to the market, and also on other borders and internal grids. For example, average flows go beyond 660MW on the Italian - Slovenian border even though there are no increases in capacity identified in the IoSN SEW-based needs grid. This reflects the real behaviour of a meshed network, which is taken into account in the zonal model used for IoSN 2040.

It is important to highlight that many borders with low transmission capacity, such as Italy-Slovenia, are often loaded at their maximum available capacity, and that the same borders are often characterised by high price spread. This clearly indicates the necessity to increase transmission capacity with new cross-border projects.

For the sake of clarity, IoSN analyses results do not always reveal such needs, because the costs expected for the additional cross-border capacity are not compared to all the benefits that may arise. A complete assessment of such cases is evaluated more deeply in the Cost Benefit Analyses carried out in TYNDP.

Given the above, the analysis carried out in the framework of the TYNDP 2020 IoSN confirms some areas of fragility on the French network, that were already identified in the French national development plan although with a higher level of congestion. This is due to a more advanced energy transition - 2040 horizon in the TYNDP vs. 2035 in the French national development plan - and an increase in exchange capacities on all borders.

#### **4.3.2 2030 horizon**

The 2030 NT scenario was assessed with an NTC model that represents different market areas, but not the physical grid. So we do not have detailed network results for this 2030 horizon.

Nevertheless, we can show the rate-of-use of cross-border capacities. This is the yearly average load shown in the following map - a value of 1 means that the cross-border capacity is fully used all year round.




Figure 4-18.a: Rate of use of cross-border capacities for NT 2030 scenario versus 2020 grid




Figure 4-18.b: Rate of use of cross-border capacities for NT 2030 scenario

With the needs identified for scenario 2030, we observe generally high rates-of-use regarding capacities, whether in one direction or the other. This illustrates the benefits of increasing cross-border



NTC in terms of exchanges allowing lower marginal costs, lower CO<sub>2</sub> emissions and higher RES generation (see Chapter 4.2)

## 5 Additional regional Studies

In order to show and demonstrate the challenges faced by the CCS power systems in the future time horizons, additional regional studies have been carried out. They focus on the influence that potential changes in CO<sub>2</sub> prices - as defined by each CCS regional group member - may have on the overall results obtained for the NT 2025 scenarios conducted at ENTSO-E level.

The simulations have been carried out in order to verify the robustness of the SoS indicators (ENS) under different circumstances, and to show how the overall balances in the CCS region and cross-border flows could be affected by these changes.

### 5.1 CO<sub>2</sub> price changes

Thermal power plants based on fossil fuels that produce high levels of CO<sub>2</sub> make up the most substantial part of the power generation mix in some CCS power systems. Therefore, changes in CO<sub>2</sub> prices significantly affect the balances and load-flow patterns in the CCS region.

This sensitivity was conducted for scenario NT 2025 from the TYNDP 2020. The CO<sub>2</sub> prices of the scenario NT 2025 (€23/ton) were changed to the prices of the DE 2030 scenario (€53/ton), which is the highest CO<sub>2</sub> price considered in the TYNDP 2020 for 2030 horizon.

The simulations have been carried out in order to show how the balances and cross-border flows in the CCS region could be affected by changing the CO<sub>2</sub> price.

Table 5-1 Comparison of the CO<sub>2</sub> prices used in the sensitivity study

CO <sub>2</sub> price base NT 2025 [€/t]	CO <sub>2</sub> price sensitivity DE 2030 [€/t]
23	53

From a market perspective, there are no load coverage problems in the region, neither in the base case nor due to the increased CO<sub>2</sub> price. The existing problem of dumped renewable energy - on average about 2.2TWh in the region - will be improved by an increased CO<sub>2</sub> price in a negligible small range of about 1%. The influence of an increased CO<sub>2</sub> price on storage behaviour in the region can be assessed as low, as the use of all storage facilities in the region has fallen by only around 14% in relation to the amount of energy stored - about 18TWh.

The results of all three market simulation tools - and three climate years - show clear correlations. Figure 5-1 shows the difference in annual energy production of those fossil technology groups showing the greatest changes. The region will become an even stronger exporter of electrical energy. The region's positive balance will increase from an average of around 35TWh - by an average of around 24TWh - to an average of around 59TWh. The largest increases in the balance are all IT bidding zones, FR00 and AT00.

These are also the bidding zones with the greatest additional CO<sub>2</sub> emissions. On the other hand, CO<sub>2</sub> emissions in DE00 decrease due to lower production from lignite and hard coal-fired power plants. In general, the higher CO<sub>2</sub> price in the region can save on average about 4Mt of CO<sub>2</sub> emissions.

The savings come from a classic fuel switch from coal, primarily lignite, to gas. On average, lignite production in the region is down by almost 20% and hard coal production by 28%. Gas production will be increased by around 27% on average, in the region. The region's additional exports therefore primarily come from gas-fired power plants, replacing lignite- and hard-coal-fired power plants in eastern European countries. These are also the bidding zones with the greatest additional CO2 emissions. On the other hand, CO2 emissions in DE00 decrease due to lower production from lignite- and hard-coal-fired power plants. In general, the higher CO2 price in the region will save on average about 4Mt of CO2 emissions.





Figure 5-1 Fossil production and CO2 Emissions difference - Sensitivity Case (€53) - Reference Case (€23)

The CO2 price increased by €30 and the resulting reduction in CO2 emissions also lead to an average increase in marginal costs of around €13 in the region. The System costs will therefore increase by an average of around €6bn or 29%.

Figure 5-2 shows the sum and direction of all market flows between the bidding areas and the balance sheets. The increased need for export in the region leads to increased exports through Germany, Austria and Slovenia - from Italy and France - into the eastern part of Europe. Therefore the need for transport - in both import and export directions - as well as between bidding zones in the region, increases. The transmission grid in the region must also meet this challenge.



This sensitivity indicates a different additional transport need in the region and demonstrates the importance of a robustly planned infrastructure. For a sustainable grid planning it is therefore important to analyse a wide range of different CO<sub>2</sub> prices.

## 6 PROJECTS

### 6.1 Pan-European projects

The map below shows all project applicants, submitted by project promoters during the TYNDP 2020 Call for projects. Projects are in different states, which are described in the CBA-guideline:

- Under Consideration
- **Planned but not permitting**
- Permitting
- Under Construction

Depending on the state of a project, it will be assessed according to the CBA.





Figure 6-1: TYNDP 2020<sup>12</sup> Projects - Regional Group CCS

<sup>12</sup> On the Italy-Slovenia border, Project 150 status on Italian side is 'in permitting', whereas on the Slovenian side it is 'under consideration'



Table 6-1: TYNDP 2020 Projects - Regional Group CCS

Project ID	Project name	Promoter	Status	Commissioning
26	Reschenpass Interconnector Project	APG, Terna	Under construction	2022/2023
28	Italy - Montenegro	Terna	Under Construction	2026
29	Italy - Tunisia	Terna	Permitting	2027
33	Central Northern Italy	Terna	Planned but not yet in permitting	2022
47	Westtirol (AT) - Vöhringen (DE)	APG, Amprion		
127	Central Southern Italy	Terna	Permitting	2024
132	HVDC Line A-North	Amprion		
150	HVDC Italy-Slovenia	ELES, Terna	Permitting <sup>13</sup>	2028 (or later in accordance with implications of the study phase on the Slovenian side)
164	N-S Eastern DE_central section	TenneT-DE		
174	Greenconnector	Worldenergy SA	Permitting	2024
186	East of Austria	APG		
187	St.Peter-Pleinting	TenneT-DE, APG		
207	Reinforcement Northwestern DE	TenneT-DE		
208	N-S Western DE_section North_1	TenneT-DE, Amprion		
228	Muhlbach - Eichstetten	Transnet, Rte		
231	Beznau - Tiengen	Swissgrid, Amprion	Under consideration	2030
235	HVDC SuedLink Brunsbüttel/Wilster to Großgartach/Grafenrheinfeld	Transnet, Tennet DE		
244	Vigy - Uchtelfangen area (HTLS/PST)	Rte, Amprion		
250	Merchant line ""Castasegna (CH) - Mese (IT)	Mera srl (a 100% subsidiary of Repower AG)	Permitting	2024
253	Uprate of Creys-St Vulbas/PST in Cornier	Rte		
254	HVDC Ultratnet Osterath to Philippsburg	Amprion, Transnet		
258	Westcoast line	TenneT-DE		

<sup>13</sup> On the Italy-Slovenia border, Project 150 status on Italian side is 'in permitting', whereas on the Slovenian side it is 'under consideration'

263	Lake Constance East	Swissgrid, VUEN	Under Consideration	2035
264	Swiss Roof I	Swissgrid	Under construction/In permitting	2029/2022/2027/2035
265	Tessin	Swissgrid	Planned but not yet permitting	2035
266	Swiss Ellipse I	Swissgrid	Under construction/In permitting	2027/2022/2029
283	Tunur	TuNur Limited		
299	SACOI3	Terna	Permitting	2024
312	St. Peter (AT)- Tauern (AT)	APG		
313	Isar/Altheim/Ottenhofen (DE) - St.Peter (AT)	TenneT-DE, APG		
322	Wullenstetten - Border Area (DE-AT)	Amprion/APG/Vuen		
323	Dekani (SI) - Zaule (IT) interconnection	Adria Link Srl, E3 d.o.o., HSE d.o.o.		
324	Redipuglia (IT) - Vrtojba (SI) interconnection	Adria Link Srl, E3 d.o.o., HSE d.o.o.		
325	Obersielach (AT) - Podlog (SI)	APG, Eles, Terna		
333	PST Foretaille	Swissgrid	Under consideration	2031
336	Prati (IT) - Steinach (AT)''	Terna	Under construction	2023
338	Adriatic HVDC link	Terna	Planned but not yet permitting	2030
339	Italian HVDC tri-terminal link	Terna	Planned but not yet permitting	2025
375	Lienz (AT) - Veneto region (IT) 220 kV	APG, Terna	Planned but not yet permitting	2026
1034	HVDC corridor from Northern Germany to Western Germany	Amprion, TenneT-DE		
1052	Lienz (AT) - Obersielach (AT)	APG		
1054	Westtirol (AT) - Zell/Ziller (AT)	APG		
1057	HVDC CentraLink	Transnet		
1058	HVDC Interconnector DE-CH	Transnet, Swissgrid	Under Consideration	2040
1059	Southern Italy	Terna	permitting	2030

## 6.2 Regional projects

In this chapter, the CCS projects of ‘regional’ and ‘national’ significance are listed, as they are needed as substantial and inherent support of the Pan-European projects inclusion into the future transmission systems. All these projects include an appropriate description and the main driver of why they are designed to be realised in the future scenarios, together with the expected commissioning dates and evolution drivers in case they were introduced in previous RegIPs.

There are no criteria for the regional significance projects inclusion in this list. They are included based purely on the project promoter’s decision if the project is relevant to be included.

In the table below, projects of regional and national significance in the CCS RG are listed.

Table 6-2: TYNDP 2020 Projects - Regional Group CCS

Country	Project Name	Investment		Expected commissioning year	Description	Main drivers	Included in RegIP 2017?
		From	To				
FR	Lille-Arras	Avelin	Gavrelle	2021	An existing 30km 400kV single-circuit OHL in the Lille area will be substituted by a new double-circuit 400kV OHL.	Security of supply and RES integration; the project aims to ensure the security of supply, taking into account RES generation volatility	Yes
FR	Sud Aveyron	-	-	2022	New substation on the 400kV Gaudière-Rueyres line for local RES integration.	RES integration	Yes
FR	Eguzon-Marmagne 400kV	Eguzon	Marmagne	2022	Reconductoring existing 400kV OHL (maintenance)	Maintenance, RES integration and market integration	Yes
FR	Long term perspective “Façade Atlantique”	-	-	>2030	Upgrade of the north-south 400kV corridor between Nouvelle Aquitaine and the Loire valley, under study.	RES integration and market integration	Yes
FR	Long term perspective “Rhône - Bourgogne”	-	-	>2030	Upgrade of the north-south 400kV corridors between Lorraine and Alsace and Franche-Comté, between Champagne-Ardenne and Bourgogne and in the Rhone valley. Upgrade of the 400kV east-west corridors between Languedoc and the Rhone valley and in the West of Provence. Under study.	RES integration and market integration	No
FR	Long term perspective “Normandie - bassin parisien”	-	-	>2030	Upgrade of the north-south 400kV corridor between Normandy and Paris basin, under study.	RES integration	No

<b>FR</b>	Long term perspective “Massif central - Centre”	-	-	>2030	Upgrade of the north-south 400kV corridors in the Massif central-Centre, under study.	RES integration and market integration	Yes
<b>DE</b>	-	Pulgar (DE)	Vieselbach (DE)	2024	Construction of new 380kV double-circuit OHL in existing corridor Pulgar - Vieselbach (104km). Detailed information given in Germany’s Grid Development.	RES integration/Security of supply	Yes
<b>DE</b>	-	Hamburg/Nord (DE)	Hamburg/Ost (DE)	2030	Reinforcement of existing 380kV OHL Hamburg/Nord - Hamburg/Ost. Detailed information given in Germany’s Grid Development.	RES integration	Yes
<b>DE</b>	-	Hamburg/Ost (DE)	Krömmel (DE)	2030	New 380kV OHL in existing corridor Krömmel - Hamburg/Ost. Detailed information given in Germany’s Grid Development.	RES integration	Yes
<b>DE</b>	-	Elsfleth/West (DE)	Ganderkesee (DE)	2030	New 380kV OHL in existing corridor for RES integration between Elsfleth/West, Niedervieland and Ganderkesee	RES integration	Yes
<b>DE</b>	-	Dollern (DE)	Alfstedt (DE)	2029	New 380kV OHL in existing corridor in Northern Lower Saxony for RES integration	RES integration	Yes
<b>DE</b>	-	Alfstedt (DE)	Elsfleth/West (DE)	2029	New 380kV line Alfstedt - Elsfleth/West in existing corridor for RES integration	RES integration	No
<b>DE</b>	-	Emden (DE)	Halbmond (DE)	2029	New 380kV line Emden - Halbmond for RES integration. Construction of new substation Halbmond	RES integration	No
<b>DE</b>	-	Conneforde (DE)	Unterweser (DE)	2030	New 380kV OHL in existing corridor for RES integration in Lower Saxony	RES integration	Yes
<b>DE</b>	-	Wolmirstedt (DE)	Klostermansfeld (DE)	2030	New 380kV OHL in existing corridor for RES	RES integration	

					integration between Wolmirstedt - Klostermannsfeld		
DE	-	Klostermannsfeld (DE)	Schraplau/Obhausen - Lauchstädt (DE)	2030	New 380kV OHL in existing corridor between Klostermannsfeld - Schraplau/Obhausen - Lauchstädt. Detailed information given in Germany's Grid Development.	RES integration	Yes
DE	-	Point Kriftel (DE)	Farbwerke Höchst-Süd (DE)	2022	The 22kV substation Farbwerke Höchst-Süd will be upgraded to 380kV and integrated into the existing grid.	RES integration/Security of supply	Yes
DE	-	Several		2030	Vertical Measures in the Ampriion zone	RES integration/Security of supply	Yes
DE	-	Büttel (DE)	Wilster/West (DE)	2030	New 380kV line in existing corridor in Schleswig - Holstein for integration of RES particularly wind on- and offshore	RES integration	Yes
DE	-	Brunsbüttel (DE)	Büttel (DE)	2030	New 380kV line Brunsbüttel - Büttel in existing corridor for RES integration	RES integration	No
DE	-	Wilster/West (DE)	Stade/West (DE)	2030	New 380kV line Wilster/West - Stade/West in existing corridor for RES integration	RES integration	No
DE	-	junction Mehrum (DE)	Mehrum (DE)	2021	New 380kV line junction Mehrum (line Wahle - Grohnde) - Mehrum including a 380/220kV transformer in Mehrum	RES integration	Yes
DE	-	Borken (DE)	Mecklar (DE)	2023	New 380kV line Borken - Mecklar in existing corridor for RES integration	RES integration	Yes
DE	-	Borken (DE)	Gießen (DE)	2030	New 380kV line Borken - Gießen in existing corridor for RES integration	RES integration	Yes
DE	-	Borken (DE)	Twistetal (DE)	2023	New 380kV-line Borken - Twistetal in existing corridor for RES integration	RES integration	Yes

DE	-	Wahle (DE)	Klein Ilsede (DE)	2021	New 380kV line Wahle - Klein Ilsede in existing corridor for RES integration	RES integration	Yes
DE	-	Birkenfeld (DE)	Ötisheim (DE)	2021	A new 380kV OHL Birkenfeld-Ötisheim (Mast 115A)	Security of supply	Yes
DE	-	Bürrstadt (DE)	BASF (DE)	2021	New line and extension of existing line to 400kV double-circuit OHL Bürrstadt - BASF including extension of existing substations.	RES integration/Security of supply	Yes
DE	-	Neuenhagen (DE)	Vierraden (DE)	2022	A new 380kV double-circuit OHL Neuenhagen - Vierraden - Bertikow with 125km length as prerequisite for the planned upgrading of the existing 220kV double-circuit interconnection Krajnik (PL) - Vierraden (DE Hertz Transmission). Detailed information given in Germany's Grid Development.	RES integration/Security of supply	Yes
DE	-	Neuenhagen (DE)	Wustermark (DE)	2021	Construction of new 380kV double-circuit OHL between the substations Wustermark and Neuenhagen with 75km length. Support of RES and conventional generation integration, maintaining of security of supply and support of market development. Detailed information given in Germany's Grid Development.	RES integration/Security of supply	Yes
DE	-	Pasewalk (DE)	Bertikow (DE)	2023	Construction of new 380kV double-circuit OHLs in North-Eastern part of 50HzT control area and decommissioning of existing old 220kV double-circuit OHLs, incl. 380kV	RES integration/Security of supply	Yes



					OHL Bertikow - Pasewalk (30km). Support of RES and conventional generation integration in North Germany, maintaining of security of supply and support of market development. Detailed information given in Germany's Grid Development.		
DE	-	Röhrsdorf (DE)	Remptendorf (DE)	2025	Construction of new double-circuit 380kV OHL in existing corridor Röhrsdorf - Remptendorf (103km)	Security of supply	Yes
DE	-	Vieselbach (DE)	Mecklar (DE)	2027	New double circuit OHL 380kV line in existing OHL corridor. Detailed information given in Germany's Grid Development.	RES integration	Yes
DE	-	Area of Altenfeld (DE)	Area of Grafenrheinfeld (DE)	2029	New double circuit 380kV OHL in existing corridor (27km) and new double circuit 380kV OHL (81km). Detailed information given in Germany's Grid Development Plan.	RES integration	TYNDP 2016
DE	-	Gießen/Nord (DE)	Karben (DE)	2025	New 380kV-line Gießen/Nord - Karben in existing corridor for RES integration	RES integration	Yes
DE	-	Herbertingen/Area of Constance/Beuren (DE)	Gurtweil/Tiengen (DE)	2030	Upgrade of the existing grid in two circuits between Gurtweil/Tiengen and Herbertingen. New substation in the Area of Constance	Security of supply	No
DE	-	Schraplau/Obhausen (DE)	Wolkramshausen (DE)	2030	New 380kV OHL in existing corridor between Querfurt and Wolkramshausen. Detailed information given in Germany's Grid Development.	RES integration	No

DE	-	Marzahn (DE)	Teufelsbruch (DE)	2030	AC grid reinforcement between Marzahn and Teufelsbruch (380kV cable in Berlin). Detailed information given in Germany's Grid Development.	Security of supply	No
DE	-	Güstrow (DE)	Gemeinden Sanitz/Dettmannsdorf (DE)	2025	New 380kV OHL in existing corridor between Güstrow - Bentwisch - Gemeinden Sanitz/Dettmannsdorf. Detailed information given in Germany's Grid Development.	RES integration	No
DE	-	Bentwisch (DE)	Bentwisch (DE)	2025	This investment includes a new 380/220kV transformer in Bentwisch.	RES integration	No
DE	-	Güstrow (DE)	Pasewalk (DE)	2030	New 380kV OHL in existing corridor between Güstrow - Siedenbrünzow - Alt Tellin - Iven - Pasewalk. Detailed information given in Germany's Grid Development.	RES integration	No
DE	-	Wolkramshausen (DE)	Vieselbach (DE)	2030	New 380kV OHL in existing corridor between Wolkramshausen - Ebeleben - Vieselbach. Detailed information given in Germany's Grid Development.	Security of supply	no
DE	-	Bürrstadt (DE)	Kühmoos (DE)	2023	An additional 380kV OHL will be installed on an existing power poles.	RES integration/Security of supply	No
DE	-	Wolmirstedt (DE)	Wahle (DE)	2026	New 380kV OHL in existing corridor between Wolmirstedt - Helmstedt - Hattorf - Wahle. Detailed information given in Germany's Grid Development.	RES integration	Yes
DE	-	Wolmirstedt (DE)	Mehrum/Nord (DE)	2030	New 380kV OHL in existing corridor between Wolmirstedt - Helmstedt - Gleidingen/Hallendorf -	RES integration	

					Mehrum/Nord. Detailed information given in Germany's Grid Development.		
DE	-	Oberbachern (DE)	Ottenhofen (DE)	2029	Upgrade of the existing 380kV line. Detailed information given in Germany's Grid Development.	RES integration/Security of supply	No
DE	-	Urberach (DE)	Daxlanden (DE)	2024	Upgrade of existing 380kV-lines in the region Frankfurt-Karlsruhe	RES integration	No
DE	-	Daxlanden (DE)	Eichstetten (DE)	2028	Upgrade of existing 220kV lines from Daxlanden via Bühl, Kuppenheim and Weier to Eichstetten to 380kV	RES integration	No
DE	-	Pulverdingen (DE)	Engstlatt (DE)	2030	Upgrade of existing 380kV corridor between Pelverdingen - Oberjettingen and Oberjettingen - Engstlatt. Extension of substation Pulverdingen is included.	RES integration	No
DE	-	Kreis Segeberg (DE)	Siems (DE)	2026	New 380kV-line Kreis Segeberg - Siems in existing corridor for RES integration	RES integration	No
DE	-	Lübeck (DE)	Göhl (DE)	2027	New 380kV-line Lübeck - Göhl for RES integration. Construction of new substation in Göhl	RES integration	No
DE	-	Grafenrheinfeld (DE)	Großgartach (DE)	2025	Additional 380kV circuit and reinforcements in existing corridor between Grafenrheinfeld and Großgartach;	RES integration	No
DE	-	Raitersaich (DE)	Altheim (DE)	2028	New 380kV-line Raitersaich - Altheim in existing corridor for RES integration	RES integration	No
DE	-	Redwitz (DE)	Schwandorf (DE)	2025	New 380kV-line Redwitz - Schwandorf in existing corridor for RES integration	RES integration	No
DE	-	Güstrow (DE)	Wolmirstedt (DE)	2022	New 380kV OHL in existing corridor between	RES integration	

					Güstrow - Parchim/Süd - Perleberg - Stendal/West - Wolmirstedt. Detailed information given in Germany's Grid Development.		
DE	-	Grid of TransnetBW		2035	Construction of several reactive power compensation systems in the area of the TransnetBW GmbH	RES integration	No
DE	-	Krümmel (DE)	Wahle (DE)	2030	Including Ad-hoc-Maßnahme Serienkompensation Stadorf-Wahle	RES integration	No
DE	-	Bechterdissen	Ovenstädt	2030	Reinforcement of existing 380kV-line between Bechterdissen and Ovenstädt	RES integration	No
DE	-	Großkrotzenburg (DE)	Urberach (DE)	2027	Reinforcement of existing 380kV-line between Großkrotzenburg and Urberach	RES integration	No
DE	-	Wilhelmshaven 2 (DE)	Fedderwarden (DE)	2030	New 380kV-line Wilhelmshaven 2 - Fedderwarden for RES integration	RES integration	No
DE	-	Redwitz (DE)	Border Bayern/Thüringen	2021	Reinforcement of existing 380kV-line between Redwitz - Border Bayern/Thüringen	RES integration	No
DE	-	Point Blatzheim (DE)	Oberzier (DE)	2025	Reinforcement of existing 380kV-line between point Blatzheim and Oberzier	RES integration	No
DE	-	Landesbergen (DE)	Mehrum/Nord (DE)	2030	New 380kV-line Kreis Segeberg - Siems in existing corridor for RES integration	RES integration	No
DE	-	Höpfingen (DE)	Hüffenhardt (DE)	2030	Additional 380kV line between Höpfingen and Hüffenhardt	RES integration	No
DE	-			Until 2030	Phase-shifting transformers in the Saarland	RES integration	No
DE	-	Hanekenfähr (DE)	Gronau (DE)	Until 2030	Reinforcement of existing/ new 380kV-line between Hanekenfähr and Gronau	RES integration	No

DE	-			2023	Ad-hoc phase-shifting transformers in the Ruhr region	RES integration	No
DE	-	Hamburg/Ost (DE)		2022	4 PST in substation Hamburg/Ost	RES integration	No
DE	-	Hanekenfähr (DE)		2023	Ad-hoc-phase-shifting transformers in Hanekenfähr	RES integration	No
DE	-	Oberzier (DE)		2023	"Ad-hoc-phase-shifting transformers in Oberzier"	RES integration	No
DE	-	Wilster/West (DE)		2023	"New phase-shifting transformers in Wilster/West"	RES integration	No
DE	-	Würgau		2023	"New phase-shifting transformers in Würgau"	RES integration	No
DE	-	Pulverdingen (DE)		2023	New phase-shifting transformer in Pulverdingen	RES integration	No
DE	-	Twistetal		2025	New phase-shifting transformers in Twistetal	RES integration	No
DE	-	Güstrow (DE)		2025	4 PST in substation Güstrow	RES integration	No
DE	-	Lauchstädt + Weida (DE)		2025	This investment includes two new 380/220kV transformers in Lauchstädt and a new 380/220kV transformer in Weida	RES integration	No
DE	-	Osterburg (DE)	Wolmirstedt (DE)	2030	New 380kV OHL in existing corridor between Osterburg - Stendal/West - Wolmirstedt. Detailed information given in Germany's Grid Development.	RES integration	No
DE	-	Substations Lauchstädt, Altenfeld, Röhrsdorf, Ragow, Siedenbrünzow, Hamburg, Neuenhagen (DE)		2030	Installation of reactive power compensation (eg MSCDN, STATCOM,...) in 50Hertz control area (substations Lauchstädt, Altenfeld, Röhrsdorf, Ragow, Siedenbrünzow, Hamburg, Neuenhagen)	RES integration/Security of supply	No
DE	-	Audorf/Süd	Ottenhofen (DE)	2025	100MW grid booster in substations		
DE	-	Grid of TenneT (DE)			Construction of several reactive power	RES integration	No

					compensation units in grid of TenneT (DE)		
DE	-	Hattingen (DE)	Linde (DE)	until 2030	Reinforcement of existing OHL between Hattingen and Linde	RES integration	No
DE	-	Enniger		2025	Phase-shifting transformers in Enniger	RES integration	No
DE	-				Several reactive power compensation systems in the area of the Amprion GmbH	RES integration	No
DE	-	Kühmoos		2024	Upgrade of substation Kühmoos in Southern Germany	RES integration	No
DE		Kupferzell		2025	500MW grid booster in substation Kupferzell	RES integration	No
DE		Siedenbrünzow (DE)	Osterburg (DE)	2025	Reinforcement of existing 380kV OHL Siedenbrünzow - Güstrow - Putlitz - Perleberg - Osterburg	RES integration	No
DE		Graustein (DE)	Bärwalde (DE)	2025	Reinforcement of existing 380kV OHL Graustein - Bärwalde	RES integration	No
DE		Ragow (DE)	Streumen (DE)	2025	Reinforcement of existing 380kV OHL Ragow - Streumen	RES integration	No
DE					Grid reinforcements in the region Büscherhof	RES integration	No
DE					Grid reinforcements in the region Aachen	RES integration	No
DE					Grid reinforcements in western Rhein region	RES integration	No
DE		Conneforde (DE)	Samtgemeinde Sottrum (DE)	2030	New 380kV line Conneforde - Sottrum in existing corridor for RES integration	RES integration	No
DE		Großgartach (DE)	Endersbach (DE)	2030	Grid reinforcements in existing corridor between Großgartach and Endersbach. Extension of substation Wendlingen is included	Security of supply	No
DE		Wolmirstedt (DE)	Wahle (DE)	2027-2029	New 380kV OHL in existing corridor. Detailed	RES integration	No

					information given in Germany's Grid Development.		
DE		Mecklar (DE)	Bergtheimfeld/West (DE)	2031	Planned, but not yet in permitting new 380kV line Mecklar - Bergtheimfeld/West	RES integration	No
DE		Dollern (DE)	Landesbergen (DE)	2026	New 380kV line Dollern - Landesbergen in existing corridor	RES integration	No
DE		Conneforde (DE)	Cloppenburg (DE)	2026	New 380kV line Conneforde - Landkreis Cloppenburg in existing corridor	RES integration	No
DE		Cloppenburg (DE)	Merzen (DE)	2026	New 380kV line Landkreis Cloppenburg - Merzen	RES integration	No
IT		Restructuring of Sorrento Peninsula network (IT)		2030	It is planned a new 380/220/150kV substation in East Vesuvius area (near Naples) connected in and out to the existing 380 and 220kV lines 'Montecorvino-S. Sofia' and 'Nola-S. Valentino'. Related to this project, it has been programmed also some reinforcements and restructuring of the existing 150kV network in the area of Sorrento Peninsula.	SoS	Yes
IT		S.Teresa (IT)	Budduso (IT)	2026	New 150kV line connecting the substation of S.Teresa, Tempio and Buddusò, allowing the realisation of a new 150kV backbone in Sardinia	RES integration, SoS	Yes
IT		Treviso (IT)		2030	New 380/132kV substations in Treviso area, connected in and out to the existing 380kV line 'Sandrigo - Cordinano'.	SoS	Yes
IT		Porto Ferrario (Elba Island)(IT)	Colmata (IT)	2025	New 40km 132kV connection via subsea cable between the existing	SoS	Yes



					substation of Porto Ferraiolo and Colmata.		
IT		Capri (IT)		Completed	New 150kV subsea connection of Capri Island to the new substations of Sorrento and Torre Annunziata (mainland Italy). New 150kV substations in Capri island and Sorrento area.	SoS	Yes
IT		Turin (IT)		2030	Restructuring of the 220kV network in the urban area of Turin. Some new 220kV cables, some new 220/132kV substations and some reinforcements of existing assets are planned.	SoS	Yes
IT		Brennero (IT)		2020	New 132kV substation with a 110/132kV PST.	Market integration	Yes
IT		Dolo (IT)	Camin (IT)	2025	New 15km double circuit 400kV underground cable between existing Dolo and Camin 400kV substations, to be built in parallel with the existing line.	SoS	Yes
IT		Media Valle Piave Razionalization (IT)		2028	Restructuring of the existing 220 and 132kV network in the Media Valle del Piave with the realisation of a new 220/132kV substation. The substation will be connected by two short links to the existing Soverzene-Lienz 220kV line.	SoS, RES integration	Yes
IT		Ciminna area (IT)		2025	For the realisation of 400kV grid reinforcement, it will be realised the voltage upgrade of the existing Ciminna substation up to 400kV.	RES integration, SoS	Yes
IT		Assoro (IT)		2030	For the realisation of 400kV grid reinforcement, it will be realised a new	RES integration, SoS	Yes

					400/150kV substation Assoro.		
IT		Chiaromonte Gulfi (IT)	Ciminna (IT)	2025	Realisation of new 400kV line: 'Chiaromonte Gulfi - new station of Assoro-Ciminna'	RES integration, SoS	Yes
IT		Sorgente 2 (IT)		2030	New 400/150kV substation in Sorgente area will be temporally connected in and out to the existing 400 line kV 'Paterno - Sorgente' and to the local 220kV and 150kV network.	RES integration, SoS	Yes
IT		Assoro (IT)	Villafranca (IT)	2030	Realisation of new 400kV line 'Assoro-Sorgente2-Villafranca'	RES integration, SoS	Yes
IT		Paternò (IT)	Priolo (IT)	2023	Realisation of new 400kV line: 'Paternò-Pantano-Priolo'	RES integration, SoS	Yes
IT		Milan (IT)	-	2025	Restructuring of the 220kV network in the urban area of Milan. Some new 220kV cables (33km), a new 220 kV substation (Musocco) and some reinforcements of existing assets (35km) are planned.	SoS	Yes
IT		Naples (IT)	-	2028	Restructuring of the 220kV network in the urban area of Naples. Some new 220kV cables and some reinforcements of existing assets are planned. Total length: 36km.	SoS	Yes
IT		Montecorvino (IT)	Benevento (IT)	2027	New 70km double circuit 400kV OHL between the existing 400kV substations of Montecorvino and Benevento II, providing in and out connection to the future substation to be built in Avellino North area, which will be also connected to the existing	Market integration	Yes

					'Matera-S. Sofia' 400kV line.		
<b>IT</b>		Palermo area (IT)		2021	Restructuring of the network in the Palermo area. The work consists of a large restructuring of the 150kV network in the Palermo area in order to increase the security and the quality of supply.	SoS	Yes
<b>SI</b>		Ravne (SI)	Ravne (SI)	2027	Construction of the new substation 220/110kV Ravne with new double 220kV OHL Ravne-Zagrad (the length is approximately 4km) and it will be included in existing interconnection 220kV OHL 220kV Podlog (SI)-Obersielach (AT). Expected commissioning date 2027.	Flicker, High load growth	Yes
<b>SI</b>	New compensation devices on 400 kV voltage level in scope of SINCRO.GRID project	Beričevo (SI), Divača (SI),	Cirkovce (SI)	2021	Installation of new compensation devices on 400kV: - SVC/STATCOM (150Mvar) in SS Beričevo, - VSR (150Mvar) and MSC (100Mvar) in SS Divača - VSR (150Mvar) in SS Cirkovce	RES integration, SoS	Yes
<b>CH</b>	Obfelden - Samstagern	Obfelden (CH)	Samstagern (CH)	2026	Reinforcement of the 220kV grid between Obfelden and Samstagern; new 220kV substations in Thalwil and Waldegg	Improvement of SoS of the Zurich area	Yes
<b>CH</b>	Flumenthal - Froloo	Flumenthal (CH)	Froloo (CH)	2036	220kV line between Flumenthal and Froloo	Improvement of SoS of the Basel area	Yes
<b>AT</b>	Refurbishment 220-kV-Line St. Peter am Hart - Ernstshofen	St. Peter am Hart (AT)	Ernstshofen (AT)	2021	Reconstruction of old 220kV Line on same route with modern bundle of two conductors.	SoS	No
<b>AT</b>	Reitdorf - Weißenbach	Pongau (AT)	Weißenbach (AT)	2023	Refurbishment of old 220kV Line on same route	SoS	No
<b>AT</b>	Weißenbach - Hessenberg	Weißenbach (AT)	Hessenberg (AT)	2025	Refurbishment of old 220kV Line on same route	SoS	No



## 7 Links to national development plans

Country	Company/TSO	National development plan
Austria	APG	<a href="http://www.apg.at/en/Stromnetz/Netzentwicklungsplan">www.apg.at/en/Stromnetz/Netzentwicklungsplan</a>
	VUEN	<a href="http://www.vuen.at">www.vuen.at</a>
France	RTE	French NDP 2016_website
Germany	Amprion	<a href="http://www.netzentwicklungsplan.de">www.netzentwicklungsplan.de</a>
	TenneT TSO	<a href="http://www.netzentwicklungsplan.de">www.netzentwicklungsplan.de</a>
	TransnetBW	<a href="http://www.netzentwicklungsplan.de">www.netzentwicklungsplan.de</a>
Italy	Terna	<a href="http://www.terna.it/it-it/sistemaelettrico/pianodisviluppodellarete/pianidisviluppo.aspx">http://www.terna.it/it-it/sistemaelettrico/pianodisviluppodellarete/pianidisviluppo.aspx</a>
Slovenia	ELES	<a href="https://www.eles.si/Portals/0/Documents/ELES-razvojni-nacrt-2019-2028.pdf">https://www.eles.si/Portals/0/Documents/ELES-razvojni-nacrt-2019-2028.pdf</a>
Switzerland	Swissgrid	<a href="https://www.swissgrid.ch/swissgrid/de/home/grid/strategic_grid_2025.html">https://www.swissgrid.ch/swissgrid/de/home/grid/strategic_grid_2025.html</a>

## 8 Appendix (additional figures)

Table 8-1: NTCs in the region 2018

FROM Country	TO Country	NTC (MW) 2018
AT	SI	950
AT	CH	1200
AT	CZ	900
AT	DE	4900
AT	HU	800
AT	ITn	315
BE	FR	1350
CH	FR	1400
CH	ITn	4240
CH	DE	4000
CH	AT	1200
CZ	AT	800
DE	FR	3000 <sup>14</sup>
DE	CH	1200
DE	AT	4900
ES	FR	3500
FR	DE	3000 <sup>7</sup>
FR	GB	2000
FR	BE	2800
FR	ES	3600
FR	ITn	3150
FR	CH	3200
FRc	ITCO	100
GB	FR	2000
GR	ITs	500
HR	SI	1600
HU	AT	800
ITn	SI	680
ITn	FR	1160
ITn	CH	1910
ITn	AT	145
ITcn	ITco	300
ITcn	ITcs	1400
ITcn	ITn	1550
ITco	FRc	150
ITco	ITcn	300
ITco	ITsar	320
ITcs	ITcn	2600
ITcs	ITs	unlimited
ITcs	ITsar	720
ITn	ITcn	3750
ITs	GR	500
ITs	ITcs	4600

<sup>14</sup> Since the application of a flow based approach, there are no historical NTCs between Germany and France for 2018. The value provided is a representative NTC, commonly agreed by German and French TSOs

<b>ITs</b>	<b>ITsic</b>	1100
<b>ITsar</b>	<b>ITcs</b>	900
<b>ITsar</b>	<b>ITco</b>	380
<b>ITsar</b>	<b>ITsic</b>	0
<b>ITsic</b>	<b>MT</b>	200
<b>ITsic</b>	<b>ITsar</b>	0
<b>ITsic</b>	<b>ITs</b>	1200
<b>MT</b>	<b>ITsic</b>	200
<b>SI</b>	<b>AT</b>	950
<b>SI</b>	<b>HR</b>	1600
<b>SI</b>	<b>ITn</b>	730 <sup>15</sup>




Figure 8-1: Inertia H[s] in all scenarios - Germany

<sup>15</sup> According to D-2 calculation, the NTC value could be higher (up to 808 MW) in a limited number of hours






Figure 8-2: Inertia H[s] in all scenarios - Austria




Figure 8-3: Inertia H[s] in all scenarios - Slovenia




Figure 8-4: Inertia  $H$ [s] in all scenarios - Switzerland




Figure 8-5: Inertia  $H$ [s] in all scenarios - France




Figure 8-6: Inertia H[s] in all scenarios - main Italian peninsula

## 9 Glossary

Term	Acronym	Definition
<b>Agency for the Cooperation of Energy Regulators</b>	ACER	EU Agency established in 2011 by the Third Energy Package legislation as an independent body to foster the integration and completion of the European Internal Energy Market both for electricity and natural gas.
<b>Baltic Energy Market Interconnection Plan in electricity</b>	BEMIP Electricity	One of the four priority corridors for electricity identified by the TEN-E Regulation. Interconnections between Member States in the Baltic region and the strengthening of internal grid infrastructure, to end the energy isolation of the Baltic States and to foster market integration; this includes working towards the integration of renewable energy in the region.
<b>Bottom-Up</b>		This approach of the scenario building process collects supply and demand data from Gas and Electricity TSOs.
<b>Carbon budget</b>		This is the amount of carbon dioxide the world can emit while still having a likely chance of limiting average global temperature rise to 1.5 C above pre-industrial levels, an internationally agreed-upon target.
<b>Carbon Capture and Storage</b>	CCS	Process of sequestering CO <sub>2</sub> and storing it in such a way that it will not enter the atmosphere.
<b>Carbon Capture and Usage</b>	CCU	The captured CO <sub>2</sub> , instead of being stored in geological formations, is used to create other products, such as plastic.
<b>Combined Heat and Power</b>	CHP	Combined heat and power generation.
<b>Congestion revenue/rent</b>		The revenue derived by interconnector owners from the sale of the interconnector capacity through auctions. In general, the value of the congestion rent is equal to the price differential between the two connected markets, multiplied by the capacity of the interconnector.
<b>Congestion</b>		Means a situation in which an interconnection linking national transmission networks cannot accommodate all physical flows resulting from international trade requested by market participants, because of a lack of capacity of the interconnectors and/or the national transmission systems concerned.
	COP 21	21st Conference of the Parties to the United Nations Framework Convention on Climate Change organised in

		2015, where participating states reached the Paris Agreement.
<b>Cost-benefit analysis</b>	CBA	Analysis carried out to define to what extent a project is worthwhile from a social perspective.
<b>Curtailed electricity</b>		Curtailement is a reduction in the output of a generator from otherwise available resources (eg wind or sunlight), typically on an unintentional basis. Curtailments can result when operators or utilities control wind and solar generators to reduce output to minimise congestion of transmission or otherwise manage the system or achieve the optimum mix of resources.
<b>Demand side response</b>	DSR	Consumers have an active role in softening peaks in energy demand by changing their energy consumption according to the energy price and availability.
<b>e-Highway2050</b>	EH2050	Study funded by the European Commission aimed at building a modular development plan for the European transmission network from 2020 to 2050, led by a consortium including ENTSO-E and 15 TSOs from 2012 to 2015 ( <a href="#">to e-Highway2050 website</a> ).
<b>Electricity corridors</b>		Four priority corridors for electricity identify by the TEN-E Regulation: North Seas offshore grid (NSOG); North-south electricity interconnections in western Europe (NSI West Electricity); North-south electricity interconnections in central eastern and south eastern Europe (NSI East Electricity); Baltic Energy Market Interconnection Plan in electricity (BEMIP Electricity).
<b>Energy not served</b>	ENS	Expected amount of energy not being served to consumers by the system during the period considered, due to system capacity shortages or unexpected severe power outages.
<b>Grid transfer capacity</b>	GTC	Represents the aggregated capacity of the physical infrastructure connecting nodes in reality; it is not only set by the transmission capacities of cross-border lines but also by the ratings of so-called 'critical' domestic components. The GTC value is thus generally not equal to the sum of the capacities of the physical lines that are represented by this branch; it is represented by a typical value across the year.
<b>Internal Energy Market</b>	IEM	To harmonise and liberalise the EU's internal energy market, measures have been adopted since 1996 to address market access, transparency and regulation,

		consumer protection, supporting interconnection, and adequate levels of supply. These measures aim to build a more competitive, customer-centred, flexible and non-discriminatory EU electricity market with market-based supply prices.
<b>Investment (in the TYNDP)</b>		Individual equipment or facility, such as a transmission line, a cable or a substation.
<b>Mid-term adequacy forecast</b>	MAF	ENTSO-E's yearly pan-European monitoring assessment of power system resource adequacy spanning a timeframe from one to ten years ahead.
<b>Net transfer capacity</b>	NTC	The maximum total exchange programme between two adjacent control areas compatible with security standards applicable in all control areas of the synchronous area and taking into account the technical uncertainties on future network conditions.
<b>N-1 criterion</b>		The rule according to which elements remaining in operation within a TSO's responsibility area after a contingency from the contingency list must be capable of accommodating the new operational situation without violating operational security limits.
<b>National Energy and Climate Plan</b>	NECP	National Energy and Climate Plans are the new framework within which EU Member States have to plan, in an integrated manner, their climate and energy objectives, targets, policies and measures for the European Commission. Countries will have to develop NECPs on a ten-year rolling basis, with an update halfway through the implementation period. The NECPs covering the first period from 2021 to 2030 will have to ensure that the Union's 2030 targets for greenhouse gas emission reductions, renewable energy, energy efficiency and electricity interconnection are met.
<b>North Seas offshore grid</b>	NSOG	One of the four priority corridors for electricity identified by the TEN-E Regulation. Integrated offshore electricity grid development and related interconnectors in the North Sea, Irish Sea, English Channel, Baltic Sea and neighbouring waters to transport electricity from renewable offshore energy sources to centres of consumption and storage and to increase cross-border electricity exchange.
<b>North-south electricity interconnections in</b>	NSI East Electricity	One of the four priority corridors for electricity identified by the TEN-E Regulation. Interconnections and internal lines in north-south and east-west directions

<b>central eastern and south eastern Europe</b>		to complete the EU internal energy market and integrate renewable energy sources.
<b>North-south electricity interconnections in western Europe</b>	NSI West Electricity	One of the four priority corridors for electricity identified by the TEN-E Regulation. Interconnections between EU countries in this region and with the Mediterranean area including the Iberian peninsula, in particular to integrate electricity from renewable energy sources and reinforce internal grid infrastructures to promote market integration in the region.
<b>Power to gas</b>	P2G	Technology that uses electricity to produce hydrogen (Power to Hydrogen - P2H2) by splitting water into oxygen and hydrogen (electrolysis). The hydrogen produced can then be combined with CO2 to obtain synthetic methane (Power to Methane - P2CH4).
<b>Project (in the TYNDP)</b>		Either a single investment or a set of investments, clustered together to form a project, in order to achieve a common goal.
<b>Project of common interest</b>	PCI	A project which meets the general and at least one of the specific criteria defined in Art. 4 of the TEN-E Regulation and which has been granted the label of PCI project according to the provisions of the TEN-E Regulation.
<b>Put IN one at the Time</b>	PINT	Methodology that considers each new network investment/project (line, substation, PST or other transmission network device) on the given network structure one by one and evaluates the load flows over the lines with and without the examined network reinforcement.
<b>Reference grid</b>		The existing network plus all mature TYNDP developments, allowing the application of the TOOT approach.
<b>Reference capacity</b>		Cross-border capacity of the reference grid used for applying the TOOT/PINT methodology in the assessment according to the CBA.
<b>Scenario</b>		A set of assumptions for modelling purposes related to a specific future situation in which certain conditions regarding electricity and gas demand and supply, infrastructures, fuel prices and global context occur.
<b>Take Out One at the Time</b>	TOOT	Methodology that consists of excluding investment items (line, substation, PST or other transmission network device) or complete projects from the forecasted network structure on a one-by-one basis and

		to evaluate the load flows over the lines with and without the examined network reinforcement.
<b>Ten-Year Network Development Plan</b>	TYNDP	The Union-wide report carried out by ENTSO-E every other year as (TYNDP) part of its regulatory obligation as defined under Article 8, paragraph 10 of Regulation (EC) 714/2009.
<b>Top-Down</b>		The ‘Top-Down Carbon Budget’ scenario building process is an approach that uses the ‘bottom-up’ model information gathered from the gas and electricity TSOs. The methodologies are developed in line with the Carbon Budget approach.
<b>Trans-European Networks for Energy</b>	TEN-E	Policy focused on linking the energy infrastructure of EU countries. It identifies nine priority corridors (including four for electricity) and three priority thematic areas.



**ENTSO-E**

Rue de Spa 8 . 1000 Brussels . Belgium

