Project Sheet

Westcoast line

Project type	transmission
Project id	258
Created by	Lea Dehaudt
Created on	Feb 9, 2021 12:18:26 PM

Index

Key Information 3
Description 3
Project Description & Context 5
Project Investments 5
System Needs addressed by the project 5
Interconnection targets 5
Project Assessment 9
Transfer capacity increase (National Trends 2025) 9
CBA results 9
Residual impact 9
Project Costs 9

ENTSO-E

Key Information

Internal Project
AC transmission line
New

Under Construction

Description

New 380-kV-line Heide/West – Klixbüll inside Schleswig – Holstein. Main focus of the project is the integration of onshore RES – mainly wind – in Western Schleswig-Holstein. The project is labeled as PCI 1.3.2. It is the southbound connection of PCI 1.3.1. and is necessary to increase the GTC between Denmark/West and Germany by 500 MW.

Project promoters

TenneT DE

Countries

Germany

National development plan(s)

NEP2030 v2019

Additional information on the project

"German grid development plan:

http://www.netzentwicklungsplan.de/en

Project webpage (in German)

http://www.tennet.eu/de/netz-und-projekte/onshore-projekte/westkuestenleitung.html

3rd PCI-list:

https://ec.europa.eu/energy/sites/ener/files/documents/annex_to_pci_list_final_2017_en.pdf

Project sheet backlog

6 Nov. 2020 - Publication as part of the draft TYNDP 2020 package for consultation

ENTSO-E

Project Description & Context

Project Investments

Main investment(s): About 135 km new 380-kV-lines and around 10 new transformers for integration of onshore Wind in Schleswig-Holstein and increase of NTC between DE and DK

Type of element	Total route length (km)	From substation 1	To substation 2	Present status	Commissioning year	Progress of the investment	Explanation in case of delay or reclustering
AC transmission line	125	Brunsbüttel (DE)	Klixbüll (DE)	Under Construction	2022	Investment on time	

Is the project in the reference grid?

No

System Needs addressed by the project

Project promoter(s) selected up to 4 system needs that are addressed by their project in a predefined list. Available needs ranged from reduction of price differentials between countries, improvement of system flexibility and stability, enabling cost-efficient connection of high volumes of RES, improvement of voltage stability...
As part of the TYNDP 2020, ENTSO-E released a study investigating cross-border system needs in the 2030 and 2040 horizons.

The project promoter did not select any need.

Interconnection targets

In 2017, the Interconnection Target Expert Group proposed alternative indicators to the 15% interconnection criteria for every country and electrified island with a new methodology developed collaboratively between the European Commission, ENTSO-E, ENTSOG, industry, universities and other experts. The methodology is based on three indicators:
1. Price differential between EU countries, with an objective to reduce it below 2 EUR/MWh
2. Ratio between nominal transmission capacity and installed RES capacity, with a target of past 30%
3. Ratio between nominal transmission capacity and peak load, with a target of past 30%

The following maps show the ITEG methodology applied to the TYNDP 2030 scenarios, with the 2020 grid.


ITEG indicators in 2030 (National Trends), if no grid development is made after 2020
Yearly average marginal costs difference < 2.00 €/MWh
Yearly average marginal costs difference > 2.00 €/MWh
At least one of the 30% criteria show < 30%
At least one of the 30% criteria show > 30% but < 60%
Both criterias show > 60%
No interconnection targets
SE
FI
NO
EE
RU
LV
LT
DKW 1
DKE 1
RU
BY
NI
IE
UK
PL
NL
DE
UA
BE
LU
CZ
SK
MD
AT
HU
RO
FR
CH
SI
HR
IT
BA
RS
BG
XK
ME
MK
AL
TR
PT
ES
GR
CY
MA
DZ
TN
MT
ISR


ITEG indicators in 2030 (Distributed Energy), if no grid development is made after 2020
Yearly average marginal costs difference < 2.00 €/MWh
Yearly average marginal costs difference > 2.00 €/MWh
At least one of the 30% criteria show < 30%
At least one of the 30% criteria show > 30% but < 60%
Both criterias show > 60%
No interconnection targets
SE
FI
NO
EE
RU
LV
LT
DKW 1
DKE 1
RU
BY
NI
IE
UK
PL
NL
DE
UA
BE
LU
CZ
SK
MD
AT
HU
RO
FR
CH
SI
HR
IT
BA
RS
BG
XK
ME
MK
AL
TR
PT
ES
GR
CY
MA
DZ
TN
MT
ISR

ITEG indicators in 2030 (Global Ambition), if no grid development is made after 2020



Project Assessment

Transfer capacity increase (National Trends 2025)

	Border	A B	B A
Transfer capacity increase (in MW)	Internal (Germany)	500	500

CBA results

ENTSO-E has assessed the benefits delivered by each project in 2025 (scenario National Trends 2025) and in 2030 (three scenarios: National Trends, Distributed Energy and Global Ambition). Indicators B1 to B6 were computed by ENTSO-E, while promoters had the possibility to compute and submit so-called project-level benefits (B7 to B10). The benefits must be understood as benefits for Europe as a whole, not for the promoters of the project.
Results are presented per scenario.

This project chose not to request a cost-benefit analysis in the TYNDP 2020. The possibility to opt out of the CBA was offered to projects under construction or to very long-term project commissioning after 2035.

Residual impact

Information on the residual impact of the project was provided by the project promoter(s).

Project Costs

The project costs were provided by the project promoter(s).

	CAPEX (Meuro)	Uncertainty range (%)	OPEX
667. Heide/West - Klixbüll	360	+-10%	2.9
Total	360		2.9

Explanation provided by the project promoter on the CAPEX uncertainty range:

667